

FINAL

TECHNICAL MEMORANDUM



South Oxnard Plain Brackish Water Treatment Feasibility Study



AUGUST 2014

 **carollo**
Engineers...Working Wonders With Water®



**UNITED WATER CONSERVATION DISTRICT
SOUTH OXNARD PLAIN BRACKISH WATER
TREATMENT FEASIBILITY STUDY**

TECHNICAL MEMORANDUM

August 2014

UNITED WATER CONSERVATION DISTRICT
SOUTH OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY STUDY
TECHNICAL MEMORANDUM

TABLE OF CONTENTS

	<u>Page No.</u>
1.0 EXECUTIVE SUMMARY	1
2.0 BACKGROUND	4
3.0 WATER QUALITY.....	5
3.1 Required Capacity	5
3.2 Proposed Well Field	7
3.3 Raw Water Quality	8
3.4 Product Water Quality	16
3.5 Concentrate Water Quality and Disposal Considerations	17
4.0 DESIGN CRITERIA	19
4.1 Process Selection.....	19
4.2 System Hydraulics and Plant Hydraulic Profile	22
4.3 Desalter Preliminary Design Criteria.....	28
4.4 Site Layouts	47
5.0 COSTS AND CONCLUSIONS.....	47
5.2 Operation and Maintenance (O&M) Costs	59
5.3 Cost Summary.....	61
5.4 Conclusions.....	63
5.5 Future Project Development Activities	65
APPENDIX A – Hydraulic Modeling Results	
APPENDIX B – Scale Inhibitor Projections	
APPENDIX C – Reverse Osmosis performance projections	
APPENDIX D – Detailed O&M Estimate	
APPENDIX E – Detailed Capital Cost Estimate	

LIST OF TABLES

Table 3.1	Proposed Desalter Volumes and Capacities	6
Table 3.2	Proposed Desalter Brine Production	7
Table 3.3	Proposed Desalter Well Field	8
Table 3.4	Raw Water Quality	15
Table 3.5	Ideal Product Water Based on Agricultural Requirements	16
Table 3.6	SMP Discharge Limits	17
Table 4.1	Sand Separator Criteria	29
Table 4.2	Sulfuric Acid Design Criteria	31
Table 4.3	Scale Inhibitor Design Criteria	32
Table 4.4	Cartridge Filter Criteria	33
Table 4.5	Reverse Osmosis Feed Pump Criteria	34
Table 4.6	RO Trains	36
Table 4.7	RO Train Interstage Booster Pumps	38
Table 4.8	Reverse Osmosis Clean-in-Place System Design Criteria	39
Table 4.9	Lime Slurry Design Criteria	41
Table 4.10	Sodium Hypochlorite Design Criteria	43
Table 4.11	RO Flush Tank	44
Table 4.12	Product Water Storage Tank and Pump Station Criteria	45
Table 5.1	Operation and Maintenance Cost Assumptions	60
Table 5.2	Cost Summary	64

LIST OF FIGURES

Figure 3.1	Proposed Product Water and Brine Pipeline Routes	9
Figure 3.2	TDS in Representative Wells	11
Figure 3.3	Chloride Concentration in Representative Wells	12
Figure 3.4	Calcium Concentration in Representative Wells	13
Figure 3.5	Iron Concentration in Representative Wells	14
Figure 4.1	10,000 AFY Process Flow and Mass Balance Diagram Design Raw Water Quality	23
Figure 4.2	10,000 AFY Process Flow and Mass Balance Diagram Worst Case Raw Water Quality	24
Figure 4.3	20,000 AFY Process Flow and Mass Balance Diagram Design Raw Water ..	25
Figure 4.4	20,000 AFY Process Flow and Mass Balance Diagram Worst Case Raw Water	26
Figure 4.5	Preliminary Desalter Hydraulic Profile	27
Figure 4.6	Automatic Backwashing Sand Separator	29
Figure 4.7	Cartridge Filter Housings	33
Figure 4.8	RO Feed Pump	35
Figure 4.9	Two Stage Brackish RO Train	37
Figure 4.10	Typical CIP System	40
Figure 4.11	Typical Glass Lined Ground Storage Tank (Photo adapted from CST Industries website - http://www.cstindustries.com/products/aquastore) ..	46
Figure 4.12	Can-Mounted Vertical Turbine Product Water Pump Station	46
Figure 4.13	10,000 AFY RO Facility – Site Plan	48
Figure 4.14	10,000 AFY RO Facility – Isometric View Looking Northwest	49
Figure 4.15	10,000 AFY RO Facility – Sand Separators, Cartridge Filters, and RO Systems	50

Figure 4.16	10,000 AFY RO Facility – Chemical Storage, RO Flush Tank, and Product Water Storage	51
Figure 4.17	10,000 AFY RO Facility – Product Water Pumps, Admin/Storage/Lab/Control/Electrical Rooms	52
Figure 4.18	20,000 AFY RO Facility – Site Plan	53
Figure 4.19	20,000 AFY RO Facility – Isometric View Looking Northwest	54
Figure 4.20	20,000 AFY RO Facility – Sand Separators, Cartridge Filters, and RO Systems	55
Figure 4.21	20,000 AFY RO Facility – Chemical Storage, RO Flush Tank, and Product Water Storage	56
Figure 4.22	20,000 AFY RO Facility – Product Water Pumps, Admin/Storage/Lab/Control/Electrical Rooms	57
Figure 5.1	Potential Connection Point to SMP	58
Figure 5.2	Typical SMP Discharge Flow Measurement Station.....	59
Figure 5.3	O&M Cost Sensitivity to Power Costs – Design Raw Water at 10,000 AFY ..	61
Figure 5.4	O&M Cost Sensitivity to Power Costs – Design Raw Water at 20,000 AFY ..	62
Figure 5.5	O&M Cost Sensitivity to Power Costs – Worst Raw Water at 10,000 AFY	62
Figure 5.6	O&M Cost Sensitivity to Power Costs – Worst Raw Water at 20,000 AFY	63

SOUTH OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY STUDY

1.0 EXECUTIVE SUMMARY

United Water Conservation District (UWCD) is fostering a vision of a regional desalter on the South Oxnard Plain to utilize a local resource impaired by salt-water intrusion. The first steps in developing this vision are to:

- Confirm that a desalter is technically feasible
- Demonstrate a treated water cost that makes desalter development a viable long term water supply option

For a desalter project to be successful, three primary technical questions must be answered:

- Is there raw water available?
- Is there a viable waste brine disposal option?
- Are there customers for the treated water?

Using an assembly of data provided by UWCD, Carollo Engineers, Inc. (Carollo) was tasked with evaluating the basic technical efficacy of groundwater desalting in the South Oxnard Plain and developing conceptual facility concepts and estimates of capital and operating costs.

In order to define the treatment process, raw water quality and finished water goals must be established. UWCD provided water quality data for three representative wells, and the qualities were blended to develop a composite design water quality with a total dissolved solids (TDS) of approximately 6,400 mg/L. A “worst case” water quality was developed by increasing the individual ions by 50 percent, resulting in a raw water TDS of approximately 9,600 mg/L. Therefore, the raw water quality for design ranges from a 6,000 to 10,000 mg/L TDS. Product water quality was defined by UWCD and is consistent with the local growers’ needs for irrigation. Based on the raw water quality and product water goals, reverse osmosis (RO) was selected as the most appropriate desalination technology. Further, the proximity of the Salinity Management Pipeline (SMP), constructed and operated by Calleguas Municipal Water District (CMWD), provides a reliable long-term solution for disposal of the brine residuals from the desalter.

Using the water quality information, design criteria were developed for a 10,000 acre-ft/yr (AFY) desalter and a 20,000 AFY desalter. The primary components of the facilities include:

- Wells
- Raw Water Pipelines
- RO Pretreatment
 - Sand Separators
 - Acid Addition
 - Cartridge Filtration
 - Scale Inhibitor Addition
- Reverse Osmosis Systems
 - High Pressure Feed Pumps
 - Membranes and Pressure Vessels
 - Clean-In-Place System
 - RO Flushing System
- Post Treatment
 - Lime addition
 - Chlorine addition
- Product Water Storage
- Product Water Pumping
- Product Water Pipelines to the PTP and PVCWD distribution systems

Estimated unit operating cost assumptions, and site layouts generated for both the 10,000 AFY and 20,000 AFY facilities, budget level capital and operating costs were developed using the developed design criteria. The capital cost for both raw water quality conditions is the same for the RO facility, as it is assumed that the full-scale facility would be capable of accommodating the proposed water quality range. A summary of the costs are as follows:

- Design Water Quality
 - 10,000 AFY
 - Capital Cost = \$85,137,000
 - Operating Cost = \$653/AF
 - Amortized Cost = \$1,111/AF

- 20,000 AFY
 - Capital Cost = \$147,966,000
 - Operating Cost = \$601/AF
 - Amortized Cost = \$998/AF
- Worst Case Water Quality
 - 10,000 AFY
 - Capital Cost = \$85,137,000
 - Operating Cost = \$821/AF
 - Amortized Cost = \$1,278/AF
 - 20,000 AFY
 - Capital Cost = \$147,966,000
 - Operating Cost = \$733/AF
 - Amortized Cost = \$1,130/AF

Based on the information provided by UWCD, SMP costs provided by CMWD, and the process selection, design criteria development, and cost information generated by Carollo, the following conclusions were made:

- The impaired groundwater in the South Oxnard Plain is suitable for treatment by reverse osmosis at an acceptable recovery range of 72 to 80 percent.
- With the exception of pH, the “ideal” product water quality can be met with traditional pretreatment, desalination, and post treatment systems.
- An amortized water cost of \$998 to \$1,111 per AF for the design water condition is competitive with imported water and has superior quality.
- Utilizing impaired groundwater treated to low TDS levels reduces salt import into the region, unlike irrigation with imported water.
- Connection to the SMP at the intersection of Hueneme Road and Edison Avenue is a viable option for concentrate disposal.
- Additional water quality sampling should be performed to confirm that the RO concentrate will comply with the SMP NPDES permit discharge limits.

2.0 BACKGROUND

Many agencies and users in Ventura County, particularly the Calleguas Creek Watershed, have seen an increase in salinity in both groundwater and surface water supplies. The source of the salts is a combination of agricultural, industrial, and residential activities in conjunction with salts in the water imported through the State Water Project.

When early settlers began pumping on the Oxnard Plain to support farming activities, the recipe was in place for the eventual overdraft of the groundwater. For nearly 100 years, United Water Conservation District has battled groundwater overdraft through a combination of aquifer recharge and alternative surface water supplies. Despite these efforts, salt-water intrusion has occurred in the southern Oxnard Plain. Unlike coastal Los Angeles and Orange County, Ventura County has no salt-water intrusion barrier in place, and the salt-impairment renders the groundwater useless for agricultural or potable uses. In fact, chloride levels in the southernmost areas of the Plain are approaching true seawater concentrations, as shown in the graphics provided by UWCD in the Request for Proposals for this project.

Managing the increase in salts will require demineralization of the water, leading many water supply agencies in Ventura County to investigate the efficacy of mining impaired groundwater for potable and non-potable uses. Specifically, UWCD is fostering a vision of a regional desalter on the South Oxnard Plain, where salt water intrusion into the shallow aquifer has occurred. The first steps in developing this vision are to:

- Confirm that a desalter is technically feasible
- Demonstrate a treated water cost that makes desalter development a viable long term water supply option

For a desalter project to be successful, three primary technical questions must be answered:


- Is there raw water available?
- Is there a viable waste brine disposal option?
- Are there customers for the treated water?

Using an assembly of data provided by UWCD, Carollo Engineers, Inc. (Carollo) was tasked with evaluating the basic technical efficacy of groundwater desalting in the South Oxnard Plain and developing conceptual facility concepts and estimates of capital and operating costs. This memorandum presents the results of this analysis, and is organized as follows:

- Section 3: Water Quality
 - An evaluation water quality data provided by UWCD, establishment of design and worst-case raw water quality, and definition of finished water goals.
- Section 4: Design Criteria
 - A discussion of technology selection, specific unit processes components and sizing, raw and product water transmission, and facility site plan and layout.
- Section 5: Capital and Operating Cost Opinion
 - A breakdown of the capital and operating costs, including unit cost assumptions, and amortized costs for two capacities and composite water qualities.

3.0 WATER QUALITY

Throughout this report, the groundwater supply pumped to the proposed treatment facility is referred to as raw water. The output of the treatment facility is referred to as product water, which is either treated water from the facility or a blend of treated and raw water that meets the effluent quality standards. A fundamental rule in water treatment is that the treatment process will be determined based on the design raw water quality and the product water quality goals.



For the South Oxnard Plain desalter, raw water quality and finished water goals were provided to Carollo by UWCD and were used to establish the treatment process. The proposed treatment facility includes among its primary objectives the removal dissolved salts, for example, sodium and chloride ions, from the raw water. Other raw water contaminants are also removed, but the treatment facility is referred to herein as a “desalter” to reflect the removal of salinity and in keeping with standard local terminology.

3.1 Required Capacity

For the purposes of this report, the required product water capacity has been defined as either 10,000 acre-feet per year (AFY) or 20,000 AFY; consequently, tabulations of capacity indicate both values. Capacity requirements for the proposed desalter are expressed in terms of annual volumes and nameplate capacity in Table 3.1.

Annual Product Water (AFY)	Annual Raw Water (AFY)	Desalter Nameplate Capacity (mgd)	Overall Desalter Recovery (percent)	Desalter Operation Factor (percent)
10,000	13,900 to 12,500	8.9	72 to 80	98
20,000	27,800 to 25,000	17.8	72 to 80	98

Table 3.1 refers to two parameters that determine raw water volume and desalter nameplate capacity for a given annual product water requirement.

- Recovery is the efficiency of the treatment facility in transforming raw water into product water; in other words, $Recovery = \frac{Product\ Water\ Volume}{Raw\ Water\ Volume}$. Overall desalter recovery is dependent upon the processes used and the amount of raw water bypass (if any). As discussed later, an overall desalter recovery range of 72 to 80 percent has been selected for this report and is reflective of both the design and worst-case raw water qualities.
- Operation factor is the ratio between the nameplate capacity of a facility and the annual average flow required to deliver a specified volume of water per year. The operation factor accounts for the fact that facilities are generally unable to operate continuously at nameplate capacity for an entire year.¹ Because of the simplicity of the proposed system and the redundancy assumed for the raw water well field, a desalter operating factor of approximately 98 percent is appropriate.

The nameplate capacity of the desalter is the instantaneous product water flow rate capacity. The nameplate capacity is higher than the average annual flow required to produce the annual product water volume by the ratio of the operation factor.

Similarly, the annual raw water volume is greater than the annual product water volume by the ratio of the overall desalter recovery. The difference between the raw water volume and the product water volume is the amount of treatment byproduct waste. The waste volume is referred to herein as brine because of its high salinity.

¹ The operation factor accounts for equipment downtime for repairs, cleaning, replacement and maintenance, power outages and other shutdowns, both planned and unplanned.

The brine production of the proposed desalter facility is indicated in Table 3.2.

Product Water (AFY)	Brine (AFY)	Desalter Nameplate Capacity (mgd)	Brine Flow at Desalter Nameplate Capacity (mgd)	Overall Recovery (percent)
10,000	3,900 to 2,500	8.9	3.47 to 1.79	72 to 80
20,000	7,800 to 5,000	17.8	6.95 to 3.57	72 to 80

3.2 Proposed Well Field

The number of wells required for the proposed South Oxnard Plain Well Field depends upon the following parameters.

- The product water requirement, which is either 10,000 AFY or 20,000 AFY.
- The overall desalter recovery, which is assumed as 80 percent for the design raw water and 72 percent for the worst-case raw water.
- The overall well field operating factor, which is assumed as not greater than 75 percent.²
- The nameplate capacity of an individual well, which is assumed as 2,000 gpm, or 2.88 mgd.³

The well field operating factor represents the ratio of the total nameplate capacity of the wells and the required volume of raw water per year, expressed as an annual average flow. The risk of *not* producing the required annual product water delivery volume increases as the well field operating factor increases.

² This is a typical well field operating factor for a high reliability water supply. For example, the Chino Basin Desalter Authority (CDA) currently operates two well fields to support two desalters producing approximately 10,000 AF/yr of product water for municipal use. The CDA has “take or pay” contracts with its member agencies and there are significant ramifications if it were unable to produce the required annual contract volumes. The CDA has established criteria of operating factors not less than 70 percent for each well field.

³ This is the proposed nameplate capacity per well given in the project kickoff meeting held March 27, 2014 (see minutes dated April 8, 2014).

Using the previously stated assumptions, Table 3.3 indicates the number of wells needed to produce the raw water required for treatment of 10,000 AFY and 20,000 AFY of product water. The number of wells required has been rounded up to the next integer value and the well field operating factor adjusted accordingly.

Product Water (AF/year)	Raw Water (AF/year)	Average Capacity per Well (gpm)	Number of Wells Required (No.)	Overall Well Field Operating Factor (percent)
10,000	13,889	2,000	4	108
			5	86
			6	72
20,000	27,778	2,000	10	86
			11	78
			12	72

Note:
 (1) Bold indicates acceptable well field operating factor (i.e., ≤ 75%)


Proposed well locations and pipelines to the desalter facility are shown in Figure 3.1.

3.3 Raw Water Quality

UWCD has provided water quality data for three wells that are proposed as representative of the desalter well field quality.⁴ Although the wells vary in water quality, it is assumed that UWCD would operate wells in various locations to provide a blended water quality that is within the design parameters of the proposed desalter, even under changing water quality conditions.⁵

⁴ Water quality files are “1990-91 USGS Rasa_wq - coastal.xlsx” and “Brackish Study WQ Export.xlsx” provided by Dan Detmer via email dated March 25, 2014.

⁵ See minutes of the project kickoff meeting held March 27, 2014 (minutes dated April 8, 2014).



- PWWCD System
- PTP System
- New Pipelines
- Salinity Management Pipeline
- Coastal Commission Jurisdictional Boundary
- New Wells

PROPOSED PRODUCT WATER AND BRINE PIPELINE ROUTES

FIGURE 3.1

UNITED WATER CONSERVATION DISTRICT
 OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY

The three wells that represent the range of potential raw water quality for the well field are as follows.


- Well SW-195 (State ID: 01N22W27C03S)
- Well CM7-190 (State ID: 01N22W27R04S)
- Well CM4-275 (State ID: 01N22W28G04S)

Water quality data provided by UWCD cover a period of approximately 15 years with data collected four times per year for some parameters of interest (e.g., chlorides and TDS) and less frequently, once or twice per year at the most, for other parameters of interest (e.g., calcium, silica and iron).

The water quality in the three representative wells has changed significantly over the past 15 years. As indicated on the following figures, the last four years of record (November 2009 – December 2013) are used for the purposes of creating a current composite raw water quality for design criteria.

- Figure 3.2 indicates TDS levels.
- Figure 3.3 indicates chloride levels.
- Figure 3.4 indicates calcium levels.
- Figure 3.5 indicates iron levels.

Table 3.4 indicates the average water quality for each of the three wells over the past four years for parameters of interest. The water quality data for the individual wells were blended to provide a composite current design water quality with a TDS of approximately 6,400 mg/L. A “worst case” water quality was developed by increasing the individual ions by 50 percent, resulting in a raw water TDS of approximately 9,600 mg/L. Therefore, the raw water quality for design ranges from a 6,000 to 10,000 mg/L TDS.




TDS IN REPRESENTATIVE WELLS

FIGURE 3.2

UNITED WATER CONSERVATION DISTRICT
 OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY






**CHLORIDE CONCENTRATION
IN REPRESENTATIVE WELLS**

FIGURE 3.3

UNITED WATER CONSERVATION DISTRICT
OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY






**CALCIUM CONCENTRATION
IN REPRESENTATIVE WELLS**

FIGURE 3.4

UNITED WATER CONSERVATION DISTRICT
OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY





**IRON CONCENTRATION
IN REPRESENTATIVE WELLS**

FIGURE 3.5

UNITED WATER CONSERVATION DISTRICT
OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY



	Well SW-195	Well CM7-190	Well CM4-275	Composite Design Raw Water	Composite Worst Case Raw Water
Calcium (mg/L Ca ²⁺)	139	727	1,565	810	1,216
Magnesium (mg/L Mg ²⁺)	46	374	488	303	454
Sodium (mg/L Na ⁺)	438	507	2,285	1,077	1,615
Potassium (mg/L K ⁺)	7.6	17.7	31.9	19.1	28.6
Barium (mg/L Ba ²⁺)	0.0510	0.0155	0.0515	0.0393	0.059
Strontium (mg/L Sr ²⁺)	4.9	1.3	8.3	4.8	7.2
Iron (mg/L Fe ²⁺)	0.426	1.901	6.581	2.969	4.5
Manganese (mg/L Mn ²⁺)	0.780	0.915	2.476	1.390	2.1
Ammonium (mg/L NH ₄ ⁺)	1.40	0.38	3.95	1.91	2.9
Cations (mg/L)	638	1,630	4,391	2,220	3,330
Bicarbonate (mg/L HCO ₃ ⁻)	281	192	265	246	369
Sulfate (mg/L SO ₄ ²⁻)	605	691	1,140	812	1,218
Chloride (mg/L Cl ⁻)	496	2,589	6,600	3,228	4,843
Fluoride (mg/L F ⁻)	0.37	0.47	0.29	0.38	0.6
Carbonate (mg/L CO ₃ ²⁻)	0.46	0.40	0.21	0.33	0.5
Nitrate (mg/L NO ₃ ⁻)	1.3	1.2	1.0	1.2	2
Phosphate (mg/L PO ₄ ³⁻)	3.4	1.8	0.4	1.9	2.8
Bromide (mg/L Br ⁻)	8.5	1.2	20.3	10.0	15.0
Anions (mg/L)	1,395	3,476	8,027	4,300	6,449
Silica (mg/L SiO ₂)	30.5	32.5	32.0	31.7	47.5
Boron (mg/L B)	0.888	0.098	0.258	0.415	0.622
Color	na ¹	na ¹	na ¹		
Hydrogen Sulfide (mg/L)	na ¹	na ¹	na ¹		
pH (units)	7.30	7.34	6.94	7.14	7.14

	Well SW-195	Well CM7-190	Well CM4-275	Composite Design Raw Water	Composite Worst Case Raw Water
Alkalinity (mg/l as CaCO ₃)	230	157	217	201	302
Hardness (mg/l as CaCO ₃)	537	3,355	5,919	3,270	4,906
CO ₂ (mg/L)	17.4	10.0	36.2	20.0	30.3
TOC (mg/L)	na ¹	na ¹	na ¹		
Temperature (°C)	19.1	19.1	18.4	18.9	18.9
Total Ions + SiO ₂	2,064	5,139	12,450	6,551	9,827
TDS by Evaporation at 180°C (mg/l)	1,913	7,098	16,671		
TDS by Ion Summation (mg/l)	1,921	5,041	12,315	6,426	9,639
Evaporation/Summation Ratio	1.00	1.41	1.35		
Ion Balance Deviation (%)	-2.0	-0.5	1.1	0.4	0.4
Notes:					
(1) na = not available					
(2) Includes total ions (no silica) and 49 percent of the bicarbonate concentration.					

3.4 Product Water Quality

Product water quality objectives have been provided by UWCD and are consistent with “ideal” product water based on agricultural requirements. The product water requirements are indicated in Table 3.5.

Parameter	Units	Criteria
Chloride	mg/L	< 50
Sodium	mg/L	< 50
Sulfate	mg/L	< 150
Bicarbonate	mg/L	< 150
Boron	mg/L	< 0.8
TDS	mg/L	< 600
pH	mg/L	> 6.5 and < 7.0

3.5 Concentrate Water Quality and Disposal Considerations

The Calleguas Municipal Water District (CMWD) has constructed the Salinity Management Pipeline (SMP), which will ultimately run from Simi Valley southwest to an ocean outfall in Port Hueneme. The SMP is an effective, sustainable mechanism for salt export from Ventura County. Since Phase 1 of the SMP runs west along Hueneme Road, it opens the door for desalter development on the South Oxnard Plain.

3.5.1 Discharge Limits

Discharge limits are established by CMWD in concert with the SMP NPDES permit. Table 3.6 presents the SMP discharge limits (taken from the *CMWD Salinity Management Pipeline Information for Potential Dischargers*, November 2011) for the constituents regulated by the NPDES permit.

Table 3.6 SMP Discharge Limits						
Constituent	Units	Average Monthly	Average Weekly	Daily Maximum	Instantaneous Maximum	6-month Median
N-Nitrosodiphenylamine	µg/L	182	--	--	--	--
Nitrobenzene	µg/L	358	--	--	--	--
PAH	µg/L	0.64	--	--	--	--
Arsenic	µg/L	--	--	2120	5624	368
Beryllium	µg/L	2.4	--	--	--	--
Cadmium	µg/L	--	--	292	730	73
Chromium VI	µg/L	--	--	584	1460	146
Copper	µg/L	--	--	732	2046	75
Lead	µg/L	--	--	584	1460	146
Mercury	µg/L	--	--	12	29	3
Nickel	µg/L	--	--	1460	3650	365
Selenium	µg/L	--	--	4380	10950	1095
Silver	µg/L	--	--	193	500	40
Thallium	µg/L	146	--	--	--	--
Zinc	µg/L	--	--	5,264	14,024	884
Cyanide	µg/L	--	--	292	730	73
TCDD Equivalentents	µg/L	2.85E-07	--	--	--	--
Aldrin	µg/L	0.002	--	--	--	--

Constituent	Units	Average Monthly	Average Weekly	Daily Maximum	Instantaneous Maximum	6-month Median
Chlordane	µg/L	0.002	--	--	--	--
Chlorinated Phenolics	µg/L	--	--	292	730	73
DDT	µg/L	0.012	--	--	--	--
Dieldrin	µg/L	0.003	--	--	--	--
Endosulfan	µg/L	--	--	1,314	1,971	0.657
Endrin	µg/L	--	--	0.292	0.438	0.146
HCH*	µg/L	--	--	0.58	0.88	0.29
Heptachlor	µg/L	0.004	--	--	--	--
Heptachlor Epoxide	µg/L	0.002	--	--	--	--
Non-chlorinated Phenolic Compounds	µg/L	--	--	8,760	21,900	2,190
PCBs*	µg/L	0.001	--	--	--	--
Toxaphene	µg/L	0.015	--	--	--	--
Tributyltin	µg/L	0.102	--	--	--	--
Total Residual Chlorine	µg/L	--	--	584	4,380	146
Acute Toxicity	TUa	--	--	2.46	--	--
Chronic Toxicity	TUc	--	--	73	--	--
Total Suspended Solids	mg/L	60	--	--	--	--
Settleable Solids	mL/L	1.0	1.5	--	3.0	--
Ammonia (as N)	µg/L	--	--	175,200	438,000	43,800
BOD (5-day @ 20°C)	mg/L	30	45	--	--	--
Oil and Grease	mg/L	25	40	--	75	--
Gross alpha	pCi/L	--	--	15	--	--
Gross beta	pCi/L	--	--	50	--	--
Combined Radium-226 & Radium-228	pCi/L	--	--	5.0	--	--
Tritium	pCi/L	--	--	20,000	--	--
Strontium-90	pCi/L	--	--	8.0	--	--
Uranium	pCi/L	--	--	20	--	--

The water quality data provided by UWCD does not contain information on the constituents listing in Table 3.6 (except for aluminum). For the purposes of this study, it is assumed that these contaminants are not present in the shallow aquifer at levels that would violate the discharge limits after concentration in the RO process. Carollo recommends that the UWCD implement a sampling plan to test for the constituents in Table 3.6 to confirm the stated assumption. The sampling plan should include quarterly sampling for at least one year to capture seasonal variations in quality. The suitability of the sampled wells for capturing the anticipated water quality should be verified with hydrological modeling and well pumping capability (outside to scope of this study). Wells should be pumped during sampling to ensure that the water is representative of the actual aquifer quality.

4.0 DESIGN CRITERIA

As mentioned previously, raw water quality and product water objectives determine the appropriate treatment process options. It is possible to narrow the selection among treatment alternatives that can meet the treatment objectives for a given raw water quality by differentiating them in appropriate selection criteria of importance to the application. Such selection criteria may include reliability, robustness, capital costs, and O&M costs.

4.1 Process Selection

A preliminary screening of process alternatives is used to narrow the selection to a single treatment process option.

4.1.1 Preliminary Screening of Process Alternatives

There are three basic process options to be initially evaluated for the proposed South Oxnard Plain desalter facility.

- **Reverse osmosis (RO)**: a physical membrane process that removes dissolved salts by applying pressure to promote diffusion of water through a semi-permeable membrane. This is the lowest cost treatment process that can meet the product water objectives for the proposed raw water criteria. It is the recommended process.
- **Electrodialysis reversal (EDR)**: an electrochemical separation process in which ions are transferred through ion exchange membranes by means of a DC voltage. EDR is not energy cost competitive with RO for treating the range of raw water quality (TDS = 5,000 – 10,000 mg/L) to meet the product water objective (TDS < 600 mg/L). In cases where concentrate disposal is expensive and RO systems are recovery limited by silica, higher EDR energy usage can be offset by higher recovery and lower concentrate disposal costs. However, calcium sulfate is the recovery-limiting constituent for this raw water, so EDR offers no advantage with respect to increased recovery. Therefore, EDR is not considered as the desalination process.

- Thermal distillation processes: not cost effective for treatment of brackish groundwater.

RO is proposed as the most appropriate treatment process for the proposed South Oxnard Plain desalter facility.

4.1.2 RO Process Description

Typical RO membranes used for desalting are formed as flat sheets that combine with spacers into a spiral wound membrane element. The cylindrical membrane elements are stacked in series within a pressure vessel so that pressurized feedwater can be applied to the membrane material. The pressure vessel has separate connections for feedwater, desalted water (permeate), and concentrated dissolved solids (brine).

The RO pressure vessels are staged into an array to produce desirable hydraulics for a given recovery or range of recoveries. A set of pressure vessels grouped into an array as an independent operating unit forms an RO train. Each RO train has constant capacity (measure as permeate flow), thus providing modular increments of capacity for operation of the entire RO plant.

4.1.2.1 Membrane Fouling

RO membranes are designed to remove dissolved contaminants from water but they are not intended to be exposed to particles or biology. The capacity of an RO membrane can decrease over time due to the following types of fouling.

- Particle fouling
- Mineral scaling
- Biological fouling
- Organic fouling

RO elements can be chemically cleaned in place to remove mineral fouling and some types of biological and organic fouling but they cannot be backwashed or flushed to remove particulates. The RO system must be protected from particles and biology.

Protection from biology is simplified when the raw water supply is groundwater, as is the case for the proposed South Oxnard Plain desalter. Protection from particles is provided by careful well construction practices and installation of cartridge filters upstream of the RO system. Wells that produce significant amounts of sand require an additional sand removal process (e.g., self-flushing filter screens) to prevent overloading the cartridge filters.

The recovery of an RO system is limited by the precipitation of chemical foulants in the concentrate. Operation at high recovery can require the addition of an acid (typically sulfuric acid) and scale inhibitors to the RO system feedwater in order to reduce the precipitation of the limiting foulants. Based upon the raw water quality, the limiting foulant for the proposed

desalter is calcium sulfate. Silica concentrations are in excess of solubility, but are below the 180 to 200 mg/L range that is considered reasonably controllable with current scale inhibitors.

Periodic application of clean-in-place (CIP) chemicals can remove calcium sulfate and silica foulants; however, CIP represents an added cost of operation and production downtime. In addition, the aggressive chemicals used for CIP can increase salt passage through the RO membranes and reduce the useful life of the RO elements. The RO design criteria proposed in this report are intended to limit CIP frequency to 3 times per year, on average.

4.1.2.2 Post-treatment

Carbonate alkalinity is significantly reduced via rejection by the RO membranes, but carbon dioxide gas is not. The proposed process includes raw water sulfuric acid addition to depress the feedwater pH, which helps reduce RO element fouling from iron and manganese. However, lowering the pH converts some carbonate alkalinity to carbon dioxide, which then passes through the membrane to the RO permeate. Post-treatment of the RO permeate by addition of a base is required to raise the pH to a level that, in conjunction with the permeate hardness and alkalinity, results in a stable finished water that is not corrosive to distribution system piping (existing and new). Common practice for groundwater desalters is to bypass a portion of the raw water and blend it with the treated permeate to add the necessary hardness and alkalinity to stabilize the finished water. However, due to the stringent chloride goals defined in Table 3.5, no raw water bypass is possible. Therefore, in order to achieve stable finished water, hydrated lime will be added to 1) increase RO permeate pH and convert dissolved CO₂ to bicarbonate alkalinity and 2) add calcium to increase the calcium carbonate precipitation potential (CCPP) to 4 to 10 mg/L, a value recommended to protect distribution system piping from corrosion.

4.1.3 RO System Process Elements

The process flow diagram for the proposed desalter options are shown in Figures 4.1 through 4.4. The diagram shows the following major process elements.

- RO Pretreatment
 - Sand separators to remove sand or other suspended solids larger than 25 micron
 - Cartridge filters to provide the final protective barrier against suspended solids and turbidity.
 - Acid and threshold inhibitor addition for scale control to reduce mineral scaling that may foul the RO membrane elements.
- RO System
 - RO feed pumps for boosting the RO feed pressure.
 - RO membrane trains for removing dissolved solids.

- RO Post-treatment
 - pH adjustment and remineralization with hydrated lime addition.
 - Chlorination with sodium hypochlorite

Each of these process elements is presented in more detail, with preliminary design criteria, later in this section of the report.

4.2 System Hydraulics and Plant Hydraulic Profile

Raw water and product water hydraulics were modeled for both design recoveries and both product water capacities.

4.2.1 Raw Water Hydraulic Modeling Parameters

Raw water pipelines were modeled as HDPE DR13.5 and sized to maintain flow velocities to not more than 5 feet per second. In order to represent worst case operating cost conditions, wells were selected that created the maximum pressure loss and energy usage. In all cases, well output was evenly distributed amongst online wells and pumping requirements were based on delivering the required feedwater at 50 psig at the entrance to the desalter.


4.2.2 Product Water Hydraulic Modeling Parameters

Product water pipelines were modeled as welded steel and sized to maintain flow velocities to not more than 5 feet per second. Additionally, pipeline sizing was selected to allow the entire product water capacity to be delivered to either the PTP or the PVCWD distribution systems. Pipeline routing to the PTP and PVCWD is presented in Figure 3.1 in Section 3.

Hydraulic model outputs are provided in Appendix A for both water quality conditions and both capacities

4.2.3 Desalter Hydraulic Profile

The proposed hydraulic profile for the RO system process is shown in Figure 4.5. The hydraulic profile shows facilities located on the South Oxnard Plain desalter site, including the membrane process, RO flush tank, product water storage tank, and product water pumping. The hydraulic profile represents a general estimate of flow conditions through the plant and includes RO feed pressure points for both the design water and worst case water, as well as product water discharge requirements at both 10,000 AFY and 20,000 AFY.





10,000 AFY Process Flow and Mass Balance Diagram Design Raw Water Quality

FIGURE 4.1

UNITED WATER CONSERVATION DISTRICT
OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY









20,000 AFY Process Flow and Mass Balance Diagram Design Raw Water

FIGURE 4.3

UNITED WATER CONSERVATION DISTRICT
OXNARD PLAIN BRACKISH WATER TREATMENT FEASIBILITY





MAIN PROCESS HYDRAULIC PROFILE
 VERTICAL SCALE: 1" = 10'

Figure No. 4.5
PRELIMINARY DESALTER HYDRAULIC PROFILE
UNITED WATER CONSERVATION DISTRICT
OXNARD PLAIN BRACKISH WATER
TREATMENT FEASIBILITY



4.3 Desalter Preliminary Design Criteria

The following material presents a brief overview of the purpose of the major process elements in the proposed desalter facility together with preliminary design criteria for each process element. Design criteria are presented for facilities required to produce annual product water volumes of 10,000 AF/yr and 20,000 AF/yr. These preliminary design criteria are the basis for both the desalter site layouts and the estimated capital and O&M costs presented in this report.

4.3.1 Sand Separators

Groundwater wells have the potential to produce significant amounts of sand. RO systems and their protective upstream cartridge filters are not designed for continuous removal of particles. Therefore, a sand separation process capable of removing sand down to 25-micron size is included in the treatment process.

The sand separators will be located on the raw water line upstream of the cartridge filters. The basic construction consists of a stainless steel main housing, inlet and outlet ports with flanged connections, stainless steel wedgewire filter elements, outlet valves and actuators, and electronic operating controls. The combination of features provides a completely automated backwashing filtration system.

The process begins with fluid passing through the inlet flange, reaching the filter elements by flowing from inside the element to outside. Solids are then trapped on the inside of the wedgewire filter element. As solids loading increases, the differential pressure between the dirty and clean side of the screens increases. When the set differential pressure is reached, typically at 7 psig, the backwash process is triggered. Alternatively, the backwash cycle can be activated based on a time setting.

The backwash process is one complete cycle, which cleans one element at a time in succession. The geared motor turns the backwash discharge arm under the filter element to be cleaned. The backwash discharge valve is then opened by a pneumatic actuator. The quick opening valve and the exposure to atmospheric pressure results in a strong pulsation and high pressure drop within the filter element being cleaned, which forces the particles into the discharge line. During this operation, a small amount of clean fluid is used to complete the cleaning process. A typical self-cleaning cycle takes less than 60 seconds. The cleaning cycle takes place with no interruption in flow to the cartridge filters, although a drop in downstream pressure is observed during each purge cycle. Typically, the flush waste will enter the plant's sewer or will discharge to the brine line

A photo of an automatic backwashing sand separator is presented in Figure 4.6. Design criteria for the sand separators are presented in Table 4.1.

Table 4.1 Sand Separator Criteria					
Description	Units	10,000 AFY		20,000 AFY	
Vessel Orientation: Vertical					
Filter Type: Wedgewire Screen					
Filter Material: 316 SST					
Filter Rating	micron	25		25	
Maximum Pressure Drop					
Clean Filter	psi	2		2	
Dirty Filter	psi	7		7	
Number of Vessels					
In-Service	No.	2		4	
Reliability	No.	0		0	
Total	No.	2		4	
Flow Per Vessel (Firm Capacity)					
Maximum (75 Percent Recovery)	gpm (mgd)	4,290	(6.18)	4,293	(6.19)
Design (83 Percent Recovery)	gpm (mgd)	3,865	(5.57)	3,863	(5.57)



Figure 4.6 Automatic Backwashing Sand Separator

4.3.2 RO Feedwater Chemical Conditioning

As water is pushed through the RO membranes, sparingly soluble salts of calcium, barium, strontium, and silica are concentrated and can precipitate on the membrane surface. The pretreatment chemicals, sulfuric acid and scale inhibitor, allow operation at supersaturated conditions for calcium carbonate, calcium sulfate, and silica, and prevent iron and manganese fouling, which in turn allows the RO systems to operate at higher system recovery. Higher recovery operation reduces the raw water requirement and the volume of waste concentrate for disposal.

The sulfuric acid storage and feed systems consist of a bulk liquid storage tank and metering pumps for delivery into the RO feedwater. Preliminary design criteria for the feedwater chemical conditioning systems are shown in Tables 4.2 and 4.3. Projections for a typical scale inhibitor are presented in Appendix B.

4.3.3 Cartridge Filters

Cartridge filters are provided as a protective measure to prevent solids from reaching the RO membrane process. Solids, such as fine sands or silts, will result in RO membrane fouling and may cause serious mechanical damage to the RO membranes. The cartridge filters are provided as the final barrier to protect the valuable RO membranes against fouling or damage from particulates.

The cartridge filter vessels share a common inlet manifold as well as a common outlet manifold. Therefore, a single cartridge filter vessel provides redundancy for the entire system if one cartridge filter vessel is out of service for maintenance or replacement of cartridges.

A photo of a cartridge filter housing is presented in Figure 4.7. Preliminary design criteria for the cartridge filters are shown in Table 4.4.

Table 4.2 Sulfuric Acid Design Criteria					
Sulfuric Acid Characteristics					
Concentration:	93 %				
Specific Gravity:	1.8				
Solution Strength:	13.94				
Parameters	Units	10,000 AFY		20,000 AFY	
		Design	Maximum	Design	Maximum
<u>Product Water</u>					
Chemical Usage					
Location: RO Feed					
Process Flow	mgd	11.1	12.4	22.3	24.7
Chemical Dose	mg/L	44.0	62.0	44.0	62.0
Chemical Usage	lb/day	4,085	6,396	8,170	12,791
Chemical Feed Rate	gpd	293	459	586	918
Chemical Feed Rate	gph	12.2	19.1	24.4	38.2
No. of Standby Pumps		1	1	1	1
No. of Pumps in Service		1	1	2	2
Chemical Feed Rate Per Pump	gph	12.2	19.1	12.2	19.1
Chemical Feed Rate Per Pump	gpm	0.20	0.32	0.20	0.32
<u>Bulk Storage Tanks</u>					
Number of Tanks	No.		1		1
Tank Capacity, each	gal		5,000		9,000
Tank Capacity, total	gal		5,000		9,000
Total Usage	gal/day		293		586
Storage Time	days		17		15
Delivery Truck Full Load	gal		3,000		3,000
Time Between Delivery	days		10		5

Table 4.3 Scale Inhibitor Design Criteria					
Scale Inhibitor Characteristics					
Avista Vitec 4000					
Concentration:	100 %				
Specific Gravity:	1.1				
Solution Strength:	9.16				
Parameters	Units	10,000 AFY		20,000 AFY	
		Design	Maximum	Design	Maximum
<u>Product Water</u>					
Chemical Usage					
Location: RO Feed					
Process Flow	MGD	11.1	12.4	22.3	24.7
Chemical Dose	mg/L	3.0	5.2	3.0	5.2
Chemical Usage	lb/day	279	536	557	1,073
Chemical Feed Rate	gpd	30	59	61	117
Chemical Feed Rate	gph	1.3	2.4	2.5	4.9
No. of Standby Pumps		1	1	1	1
No. of Pumps in Service		1	1	1	1
Chemical Feed Rate Per Pump	gph	1.3	2.4	2.5	4.9
Chemical Feed Rate Per Pump	gpm	0.02	0.04	0.04	0.08
<u>Bulk Storage Tanks</u>					
Number of Tanks	No.		1		1
Tank Capacity, each	gal		5,000		5,000
Tank Capacity, total	gal		5,000		5,000
Total Usage	gal/day		30		61
Storage Time	days		164		82
Delivery Truck Full Load	gal		3,000		3,000
Time Between Delivery	days		99		49

Table 4.4 Cartridge Filter Criteria				
Description	Units	10,000 AFY		20,000 AFY
Vessel Orientation: Horizontal				
Cartridge Filter Type: Melt Blown				
Cartridge Filter Material: Polypropylene				
Cartridge Filter End Connection: Single Open End, Double O-ring				
Cartridge Filter Rating	micron	5		5
Cartridge Filter Length	inches	40		40
Cartridge Filter Loading Rate				
Maximum (75 Percent Recovery)	gpm/10-inch	4.1		4.1
Design (83 Percent Recovery)	gpm/10-inch	3.7		3.7
Maximum Pressure Drop				
Clean Filter	psi	3		3
Dirty Filter	psi	15		15
Number of Vessels				
In-Service	No.	3		6
Reliability	No.	0		0
Total	No.	3		6
Flow Per Vessel (Firm Capacity)				
Maximum (75 Percent Recovery)	gpm (mgd)	2,860	(4.12)	2,862 (4.12)
Design (83 Percent Recovery)	gpm (mgd)	2,577	(3.71)	2,575 (3.71)
Cartridge Filters Per Vessel	No.	176		176
Total Number of Cartridges	No.	528		1,056



Figure 4.7 Cartridge Filter Housings

4.3.4 RO Feed Pumps

The purpose of the RO feed pumps is to provide the energy to overcome osmotic pressure and dynamic head losses through the RO system. Each RO feed pump is dedicated to a single RO membrane train. For maximum efficiency, RO feed pumps are multistage vertical turbines, mounted in cans with both the suction and discharge flanges on the pump head. RO feed pumps are typically located in the process room with roof hatches for crane access to the pumps (for maintenance).

A photo of a typical RO feed pump is presented in Figure 4.8. Preliminary design criteria for the RO feed pumps are shown in Table 4.5.

Table 4.5 Reverse Osmosis Feed Pump Criteria			
Description	Units	10,000 AFY	20,000 AFY
Type: Vertical Turbine in Closed Bottom Cans			
Number of Pumps			
In-Service	No.	5	10
Reliability	No.	0	0
Total	No.	5	10
Capacity (per Pump)			
Design (80 Percent Recovery)	gpm	1,546	1,545
Maximum (72 Percent Recovery)	gpm	1,716	1,717
Suction Pressure			
Maximum (Best Case)	psig	50	50
Design	psig	30	30
Discharge Pressure			
Design	psig	263	263
Maximum (Worst Case)	psig	309	309
Total Dynamic Head (TDH)			
Design	ft	538	538
Maximum (Worst Case)	ft	644	644
Motor Size			
Pump Efficiency	percent	82	82
Worst Case BHP	hp	341	341
Motor hp (per Pump)	hp	500	500
Motor hp (Total)	hp	2,500	5,000
Drive	type	VFD	VFD



Figure 4.8 RO Feed Pump

4.3.5 RO Membrane Trains

The RO trains receive pressurized feedwater from the RO feed pumps. The pressure “pushes” water through the membranes while salt is rejected. The rejected salts are concentrated into a small percentage of the flow and exit the system as waste. The proposed design criteria will allow the RO trains to operate across a recovery range of 72 to 80 percent.

A photo of a typical two stage brackish RO system is presented in Figure 4.9. Proposed design criteria for the RO trains are shown in Table 4.6.

Table 4.6 RO Trains					
Description	Units	10,000 AFY		20,000 AFY	
Type: Reverse Osmosis (RO)					
Number of Membrane Trains					
In-Service	No.	5		10	
Reliability	No.	0		0	
Total	No.	5		10	
Train Flux Rate ¹	gfd	13.2		13.2	
Recovery (Permeate/Feed Flow)					
Minimum	percent	72		72	
Design	percent	80		80	
Total Permeate Flow per Train	gpm (mgd)	1,236	(1.78)	1,236	(1.78)
Second Stage Permeate Flow per Train	gpm (mgd)	411	(0.59)	408	(0.59)
Brine Flow per Train					
Design	gpm (mgd)	309	(0.45)	309	(0.45)
Maximum	gpm (mgd)	481	(0.69)	481	(0.69)
Number of Array Stages Per Train					
1st Stage	No.	2		2	
Pressure Vessels per Train	No.	32		32	
Elements per Pressure Vessel	No.	7		7	
2nd Stage	No.	16		16	
Pressure Vessels per Train	No.	16		16	
Elements per Pressure Vessel	No.	7		7	
Number of Elements					
Per Train	No.	336		336	
Total (In-Service)	No.	1,680		3,360	
Membrane Area					
Per Element	sq. ft.	400		400	
Per Train	sq. ft.	134,400		134,400	
Total (In-service)	sq. ft.	672,000		1,344,000	
<u>Note:</u>					
(1) Flux is balanced between the RO stages using an interstage booster pumps.					



Figure 4.9 Two Stage Brackish RO Train

As shown in Table 4.6, flux balance between the first and second stage of the RO train is controlled using an interstage booster pump. Interstage boost pumps deliver pressure to the feed of the second stage to maintain a second stage permeate flowrate. The piping is configured on the RO trains to allow for operation of the system with the interstage boost pump out of service. Performance projections for the RO system design considered herein are presented in Appendix C.

Preliminary design criteria for the inter-stage booster pumps is shown in Table 4.7.

Table 4.7 RO Train Interstage Booster Pumps			
Description	Units	10,000 AFY	20,000 AFY
Type: Inline Vertical Centrifugal			
Booster Pumps Per RO Train	No.	1	1
<u>Pump Data</u>			
Stages	No.	1	1
Flow			
At 72 Percent RO Recovery	gpm	888	888
At 80 Percent RO Recovery	gpm	720	655
Total Dynamic Head at 72 Percent Recovery	ft	461	461
Total Dynamic Head at 80 Percent Recovery	ft	461	461
Motor Size			
Pump Efficiency	percent	70	70
Worst Case BHP	hp	148	148
Motor hp (per Pump)	hp	200	200
Drive	type	VFD	VFD

4.3.6 Membrane CIP System

The CIP system is used to chemically clean and remove foulants (e.g., particles, mineral scale, and biology) from the RO membranes. Foulants result in additional headloss and increased energy requirements to maintain production flow rates. Additionally, foulants may result in a deterioration of permeate water quality.

The CIP system circulates cleaning chemicals to the RO membrane trains. The CIP system is permanently connected to the membrane skid piping in order to avoid the labor, time, and safety issues involved in connecting and disconnecting hoses or pipe spools. CIP connections to the permeate side of the RO membrane will have block valves and removable spool pieces to insure that the treated water is isolated from the cleaning solution while in service.

Each stage on the membrane train is cleaned separately to deliver the required cleaning flow velocities to each pressure vessel in the array.

Preliminary design criteria for the CIP system are shown in Table 4.8. A photo of a typical CIP system is presented in Figure 4.10.

Table 4.8 Reverse Osmosis Clean-in-Place System Design Criteria		
Description	Units	Both Options
<u>Pressure Vessel Cleaning Flow Rate</u>		
Stage 1 (Flow Per Vessel)	gpm	45
Vessels Cleaned Per Cycle	No.	32
Stage 1 Cleaning Flowrate	gpm	1,440
Stage 2 (Flow Per Vessel)	gpm	45
Vessels Cleaned Per Cycle	No.	16
Stage 2 Cleaning Flowrate	gpm	720
<u>CIP Chemical Tank</u>		
Number	No.	2
Volume (Each)	gallons	4,500 (nominal)
<u>Tank Heater</u>		
Type: Immersion		
Number of Units Per Tank	No.	2
Size		
Each	kW	100
Total	kW	400
<u>CIP Recirculation Pump</u>		
Type: FRP End Suction Centrifugal		
Number	No.	1
Flow	gpm	1,440
TDH	ft H ₂ O (psig)	170
Motor Load	hp	125
Drive		VFD
<u>Cartridge Filter</u>		
Vessel Orientation: Vertical		
Cartridge Filter Type: Melt Blown		
Cartridge Filter Material: Polypropylene		
Cartridge Filter End Connection: Single Open End, Double O-Ring		
Cartridge Filter Rating	micron	5
Cartridge Filter Length	inches	40
Cartridge Filter Loading Rate		
At Maximum Flowrate	gpm/10-inch	4.19
At Minimum Flowrate	gpm/10-inch	2.09
Maximum Pressure Drop		
Clean Filter	psig	3
Dirty Filter	psig	15
Cartridge Filters per Vessel	No.	86



Figure 4.10 Typical CIP System

4.3.7 RO Permeate Chemical Conditioning

RO permeate does not meet the water quality objective for effluent pH and alkalinity without chemical conditioning. Typical practice for municipal drinking water RO facilities is addition of sodium hydroxide (caustic soda); however, for the proposed irrigation usage this has the detrimental effect of raising the sodium level resulting in a higher sodium adsorption ratio (SAR).⁶ Further, the use of caustic soda does not add calcium, which is useful, in conjunction with pH and alkalinity, to protecting distribution system piping. The proposed chemical conditioning for the South Oxnard Plain desalter is the addition of hydrated lime (as a 35 percent slurry). The advantage of adding lime is that there is no increase in sodium and the addition of calcium ions will reduce the SAR as well as increase the calcium carbonate precipitation potential (CCPP), which helps protect distribution system piping.

Chlorine, provided as sodium hypochlorite, is also added to the permeate to prevent biological growth in the distribution system. Additionally, the addition of chlorine will oxidize low levels of hydrogen sulfide. Based on information provided by UWCD, hydrogen sulfide levels in the shallow aquifer targeted for this facility are low. Therefore, for the purposes of this study, hydrogen sulfide levels are assumed to be less than 0.5 mg/L and will be managed by oxidation with chlorine in the permeate.

Preliminary design criteria for RO permeate lime and sodium hypochlorite feed systems are shown in Table 4.9 and 4.10, respectively.

$$^6 \text{ SAR} = \frac{Na}{\sqrt{\frac{1}{2}(Ca+Mg)}}$$

where sodium, calcium, and magnesium are expressed in meq/L. In general, the lower the SAR, the more suitable the water is for irrigation.

Table 4.9 Lime Slurry Design Criteria					
Lime Characteristics					
Lime Purity	%	97%			
Dry Lime Bulk Density (Storage Value)	lb/cu ft	30			
Concentration:	%	35 %			
Specific Gravity:		1.271			
Solution Strength:	lb/gal	3.70			
Parameters	Units	10,000 AFY		20,000 AFY	
		Design	Maximum	Design	Maximum
<u>Post Treatment</u>					
Chemical Usage					
Location: After RO Flush Tank					
Process Flow	mgd	8.9	8.9	17.80	17.80
Chemical Dose	mg/L	58	73	58	73
Chemical Dose (as stored weight)	mg/L	60	75	60	75
Chemical Usage	lb/day	4,441	5,589	8,882	11,179
Chemical Feed Rate	gpd	1,199	1,509	2,398	3,018
Chemical Feed Rate	gph	50.0	62.9	99.9	125.8
Number of Duty Metering Pumps	No.	1.0	1.0	2.0	2.0
Number of Standby Metering Pumps	No.	1.0	1.0	1.0	1.0
Chemical Feed Rate Per Pump	gph	50.0	62.9	50.0	62.9
<u>Lime Storage Silos</u>					
Number of Silos	No.	1		1	
Silo Capacity, each	cu ft	2,250		4,500	
Silo Capacity, each	lbs	67,500		135,000	
Silo Capacity, total	Tons	33.75		67.5	
Silo Diameter, each	ft	14		14	
Silo Sideshell Height, each	ft	15		30	
Dry Usage	lbs/day	4,441		8,882	
Dry Usage	tons/day	2.2		4.4	

Table 4.9 Lime Slurry Design Criteria					
Parameters	Units	10,000 AF/yr		20,000 AF/yr	
		Design	Maximum	Design	Maximum
Storage Time	days	15		15	
Delivery Truck Full Load	tons	24		24	
Time Between Delivery	days	10.8		5.4	
<u>Lime Slurry Storage</u>					
Number of Tanks	No.	1		1	
Tank Capacity, each	gal	9,000		9,000	
Tank Capacity, total	gal	9,000		9,000	
Total Usage	gal/day	1,199		2,398	
Storage Time	days	7.5		3.8	
Delivery Truck Full Load	gal	4,000		4,000	
Time Between Delivery	days	3.34		1.67	

Table 4.10 Sodium Hypochlorite Design Criteria			
Sodium Hypochlorite Characteristics			
Concentration:	10.5 %		
Specific Gravity:	1.15		
Solution Strength:	1.01		
Parameters	Units	Design	Design
<u>Post Treatment</u>			
Chemical Usage			
Location: After RO Flush Tank			
Process Flow	mgd	8.9	17.8
Chemical Dose	mg/L	5.0	5.0
Chemical Usage	lb/day	371	743
Chemical Feed Rate	gpd	369	739
Chemical Feed Rate	gph	15.4	30.8
No. of Standby Pumps		1	1
No. of Pumps in Service		1	2
Chemical Feed Rate Per Pump	gph	15.4	15.4
Chemical Feed Rate Per Pump	gpm	0.26	0.26
<u>Bulk Storage Tanks</u>			
Number of Tanks	No.	1	1
Tank Capacity, each	gal	5,500	11,000
Tank Capacity, total	gal	5,500	11,000
Total Usage	gal/day	369	739
Storage Time	days	15	15
Delivery Truck Full Load	gal	3,000	3,000
Time Between Delivery	days	8	4

4.3.8 RO Flush Tank

For higher TDS RO systems such as this, shutdown flushing using treated RO permeate is typical to prevent chloride corrosion of stainless steel piping and valves. Permeate storage must be free from chlorine and must also remain “fresh.” Therefore, permeate storage is configured as a flow- through tank that is fed at the bottom and overflows to the ground storage tank. In between the permeate storage tank and the ground storage tank, lime and sodium hypochlorite are added to stabilize and disinfect the product water. This arrangement prevents the chlorinated water from being introduced in the RO systems during flushing or CIP makeup, and continuously turns over the tank volume to keep the water from stagnating.

Preliminary design criteria for RO flush tank are shown in Table 4.11.

Table 4.11 RO Flush Tank			
Description	Units	10,000 AFY	20,000 AFY
<u>Product Water Storage</u>			
Type: Circular, Above-ground, FRP			
Number of Tanks	No.		1
Tank Dimensions			
Depth	ft		40
Diameter	ft		14
Volume	gallons		38,000

4.3.9 Product Water Storage and Pumps

Above ground storage can be constructed using an economical bolted steel tank with glass-lined panels that are low maintenance. Can mounted vertical turbine product water pumps are proposed to transfer water from the ground storage tank to the PTP and PVCWD systems. Vertical turbine pumps have higher efficiency than split case or other types of surface mounted pumps and have steeper performance curves that respond well on variable speed drives.

Figures 4.11 and 4.12 present a glass lined storage tank and can mounted vertical turbine product water pump station, respectively. Preliminary design criteria for the on-site product water storage and pumps are shown in Table 4.12.

Table 4.12 Product Water Storage Tank and Pump Station Criteria					
Description	Units	10,000 AF/yr		20,000 AF/yr	
<u>Product Water Pumps</u>					
Type: Vertical Turbine in Closed Bottom Cans					
Number of Pumps					
In-Service	No.	2		4	
Reliability	No.	1		1	
Total	No.	3		5	
Capacity					
Per Pump	gpm (mgd)	3,088	(4.45)	3,088	(4.45)
Firm (One Pump Out of Service)	gpm (mgd)	6,177	(8.90)	12,353	(17.80)
Total	gpm (mgd)	9,265	(13.35)	15,442	(22.25)
Total Dynamic Head Required (TDH) ¹	feet	165		135	
Motor Size					
Pump Efficiency	percent	80		80	
Required BHP	hp	161		132	
Selected	hp	200		200	
Drive	type	VFD		VFD	
<u>Product Water Storage</u>					
Type: Circular, Above-ground, Glass-lined, Steel Bolt-up Tank					
Number of Tanks	No.	1		1	
Tank Dimensions (Each) ²					
Depth	ft	27		27	
Diameter	ft	112		159	
Area	sq ft	9,852		19,856	
Volume					
Each	gallons	1,990,000		4,010,000	
Total	gallons	1,990,000		4,010,000	
Storage Time at Design Flow	hours	5.4		5.4	
Storage as Percent of Daily Flow	percent	22		23	
<u>Notes:</u>					
(1) Using 24-inch diameter pipe for 10,000 AFY capacity and 36-inch diameter pipe for 20,000 AFY capacity.					
(2) Using Manufacturer's standard dimensions.					



Figure 4.11 Typical Glass Lined Ground Storage Tank (Photo adapted from CST Industries website - <http://www.cstindustries.com/products/aquastore>)



Figure 4.12 Can-Mounted Vertical Turbine Product Water Pump Station

4.4 Site Layouts

Preliminary site layouts for the 10,000 AFY desalter facility are presented in Figures 4.13 through 4.17. Preliminary site layouts for the 20,000 AFY desalter facility are presented in Figures 4.18 through 4.22. The site layouts show all of the major process components for both the 10,000 AFY and 20,000 AFY scenarios. The primary purpose of the preliminary site layouts is to provide conceptual arrangements that furnish guidance on area requirements for the proposed desalter facility.

5.0 COSTS AND CONCLUSIONS

Estimated capital costs were developed using a combination of vendor quotes, recently bid projects, and unit cost assumptions. Carollo has recently been involved with several Southern California projects of similar scope, including:

- Chino II Desalter Expansion
- Mesa Water Reliability Facility
- Irvine Ranch Water District Well 21/22 Desalter

Costs for RO equipment, chemical feed systems, and other ancillary systems were derived from the bids for these projects.

The layouts presented in Section 4 were used to estimate building costs. Different unit costs were used for each area to reflect the level of complexity of the defined space. For example, a covered chemical storage area has a lower unit cost than administrative areas because there are limited HVAC and building mechanical requirements and no interior finishing requirements, such as drywall, paint, specialized flooring, etc. The building classifications were divided into the following categories:

- Main process areas
- Covered chemical storage areas
- Non-process areas
 - Administrative
 - Electrical Room
 - Control Room
 - Laboratory
 - Shop/Storage Area




Figure 4.13 10,000 AFY RO Facility – Site Plan



Figure 4.14 10,000 AFY RO Facility – Isometric View Looking Northwest




Figure 4.15 10,000 AFY RO Facility – Sand Separators, Cartridge Filters, and RO Systems




Figure 4.16 10,000 AFY RO Facility – Chemical Storage, RO Flush Tank, and Product Water Storage




Figure 4.17 10,000 AFY RO Facility – Product Water Pumps, Admin/Storage/Lab/Control/Electrical Rooms




Figure 4.18 20,000 AFY RO Facility – Site Plan



Figure 4.19 20,000 AFY RO Facility – Isometric View Looking Northwest




Figure 4.20 20,000 AFY RO Facility – Sand Separators, Cartridge Filters, and RO Systems




Figure 4.21 20,000 AFY RO Facility – Chemical Storage, RO Flush Tank, and Product Water Storage




Figure 4.22 20,000 AFY RO Facility – Product Water Pumps, Admin/Storage/Lab/Control/Electrical Rooms

Unit costs were applied to known quantities, such as building square footage and gallons per day of capacity. Process equipment unit costs were based on vendor quotes and historical data from past projects. Detailed breakdowns of the capital costs for the water treatment plant and pipelines are presented in Appendix D.

5.1.1 SMP Connections

Connections to the SMP are allowed through existing blowoff branches incorporated into the pipeline design, per correspondence with Kristine McCaffrey, CMWD Manager of Engineering. As shown in Figure 5.1, a 24" blowoff connection is available at Station 106+70.00 at the intersection of Hueneme Road and Edison Drive.




Figure 5.1 Potential Connection Point to SMP

Discharge stations are designed and constructed by CMWD at an estimated cost, provided by CMWD, of approximately \$300,000. The typical discharge station design is presented in Figure 5.2.




Figure 5.2 Typical SMP Discharge Flow Measurement Station

5.2 Operation and Maintenance (O&M) Costs

Operations costs were based on assumptions for:

- Power
- Chemicals
- Cartridge Filters
- Membranes
- Concentrate Disposal
- Water Quality Sampling and Analysis
- Miscellaneous Repair
- Miscellaneous Power (Lights, Air Conditioning, etc.)
- Labor

Chemical usage and power consumption were developed using data from manufacturers' projection software, water chemistry modeling, and hydraulic modeling using selected pump curves and required flow and pressure conditions for each capacity and water quality. For example, RO cleaning intervals and cleaning chemical costs were developed based on the Arlington Desalter in Southern California. Chemical costs were based on information in the *Chino Phase III Expansion Financial Projections Update* (Carollo Engineers, August 2012).

5.2.1 SMP Disposal Costs

Based on information provided by CMWD, disposal costs into the brine line are dependent upon the areas served by the water produced. For water distribution within the service area, concentrate disposal costs are \$500/AF. Because the SMP is subsidized by potable water rates, lower disposal rates apply to those discharges that are producing and distributing

potable water. Outside of the service area, including the agriculture users to be served by the South Oxnard Plain desalter via the PTP and PVCWD, cost for use of the brine line is \$750/AF. Estimated brine flows are presented in Table 3.2.

5.2.2 O&M Estimate Unit Cost Assumptions

The assumed costs used in developing O&M Costs are presented in Table 5.1. Detailed breakdowns of the O&M costs are presented in Appendix E.

Table 5.1 Operation and Maintenance Cost Assumptions	
Chemicals	
Hydrated Lime (\$/lb):	\$0.20
Sulfuric Acid (\$/lb):	\$0.034
Scale Inhibitor (\$/lb):	\$0.95
Sodium Hypochlorite (\$/lb):	\$0.35
Membranes and Filters	
Membrane Elements - 8 inch diameter(\$/element):	\$500
Cartridge Filters (\$/filter):	\$12.00
Chemical Cleanings	
Step 1 Cleaning Chemical Cost (\$/lb):	\$2.82
Step 2 Cleaning Chemical Cost (\$/lb):	\$3.16
Step 3 Cleaning Chemical Cost (\$/lb):	\$2.00
Other Non- Labor Costs	
Power (\$/kWh):	\$0.125
Miscellaneous Equipment and Building Maintenance (\$/yr):	\$50,000
Well Maintenance (% of capital cost):	2%
Laboratory Sample Analysis (\$/yr):	\$150,000
Percentage Adder for Miscellaneous Power (%):	2%
SMP Discharge (\$/AF):	750
Annual SMP Discharge Station Maintenance and Sampling (\$/yr):	\$45,000
Labor	
Annual T2 Operator Salary (\$/yr):	\$72,696
Annual T1 Operator Salary (\$/yr):	\$59,821
Fringe Percentage (%):	40%
Administrative Cost Percentage (%):	55%
Plant Operating Factor (% of Time in Operation)	98%

5.3 Cost Summary

Table 5.2 summarizes the capital and operational costs for each option. Capital costs presented herein represent a Class 4 budget estimate, as defined by the ACEI's Revised Classification (1999), with an expected accuracy range of +30 percent or -15 percent. This cost estimate is based upon Carollo Engineers' perception of current conditions in the project area and is subject to change as variances in the cost of labor, materials, equipment, services provided in the project area occur. A detailed summary of the capital cost estimate is presented in Appendix F.

The unit water cost was developed by amortizing the capital costs across a 30-year period at a 3.22 percent interest rate (term and rate provided by UWCD). The annual capital repayment was then added to the annual operation and maintenance costs. The combination of the amortized capital and operations costs constitutes the annualized costs for each alternative.

Since operating costs are sensitive to power costs, a power cost sensitivity analysis was performed for each scenario. The impact to the O&M costs was assessed between \$0.07 and \$0.15 per kWh. The results are presented in Figures 5.3 through 5.6.




Figure 5.3 O&M Cost Sensitivity to Power Costs – Design Raw Water at 10,000 AFY




Figure 5.4 O&M Cost Sensitivity to Power Costs – Design Raw Water at 20,000 AFY




Figure 5.5 O&M Cost Sensitivity to Power Costs – Worst Raw Water at 10,000 AFY




Figure 5.6 O&M Cost Sensitivity to Power Costs – Worst Raw Water at 20,000 AFY

5.4 Conclusions

The following conclusions are based on the information provided by UWCD and CMWD, and the process selection, design criteria development, and cost information generated by Carollo:

- The impaired groundwater in the South Oxnard Plain is suitable for treatment by reverse osmosis at an acceptable recovery range of 72 to 80 percent.
- With the exception of pH, the “ideal” product water quality can be met with traditional pretreatment, desalination, and post treatment systems.
- An amortized water cost of \$998 to \$1,111 per AF for the design water condition is competitive with imported water and has superior quality.
- Utilizing impaired groundwater treated to low TDS levels reduces salt import into the region, unlike irrigation with imported water.
- Connection to the SMP at the intersection of Hueneme Road and Edison Avenue is a viable option for concentrate disposal.
- Additional water quality sampling should be performed to confirm that the RO concentrate will comply with the SMP NPDES permit discharge limits.

Table 5.2 Cost Summary		10,000 AFY Design Water Quality	10,000 AFY Worst Case Water Quality	20,000 AFY Design Water Quality	20,000 AFY Worst Case Water Quality
Capital Costs					
Conceptual WTP Construction Cost Estimate (\$):		\$85,137,000	\$85,137,000	\$147,966,000	\$147,966,000
Operation and Maintenance Costs					
Annual O&M Cost (\$/yr):		\$6,383,700	\$8,021,500	\$11,737,900	\$14,316,200
Annual O&M Cost (\$/kgal):		\$2.01	\$2.52	\$1.84	\$2.2.25
Annual O&M Cost (\$/AF):		\$653	\$821	\$601	\$733
Annualized Costs					
Annual O&M Cost with Capital Recovery (\$/yr):		\$10,850,700	\$12,489,500	\$19,503,300	\$22,081,600
Annual O&M Cost with Capital Recovery (\$/kgal):		\$3.41	\$3.92	\$3.06	\$3.47
Annual O&M Cost with Capital Recovery (\$/AF):		\$1,111	\$1,278	\$998	\$1,130


5.5 Future Project Development Activities

In order to advance the desalter project beyond the feasibility level toward design and construction, several additional preliminary steps must be taken that are outside the scope of this feasibility study. These steps include:

- Well Sampling – UWCD should initiate the well sampling plan recommended in Section 3.5.1. This information will increase the water quality database to refine the process design and insure that SMP regulated contaminants are not problematic for concentrate disposal.
- Finalize GMA Agreements – UWCD has initiated conversations with the GMA regarding the utilization of the impaired groundwater and the exemption from groundwater pumping surcharges. A formal groundwater usage agreement should be finalized between the GMA and UWCD.
- Finalize Sites for Wells – Figure 3.1 presents approximate well sites based on information provided by UWCD. The well sites should be finalized, and the ability to acquire the property should be confirmed.
- Finalize Plant Site – Figure 3.1 identifies a potential location for the desalter. MWD is the owner of the parcel shown, and has earmarked that property for a future desalter. The availability of this land for use as the desalter site should be coordinated with MWD, and a finalized use agreement or property acquisition plan should be developed.
- Electrical Infrastructure Investigation – As part of the feasibility study, the capability of the SCE grid to support the desalter and wells has been confirmed. However, specifics regarding modifications and the capital cost implications have not been developed to a detailed design level. Therefore, a large load study should be performed by SCE to establish infrastructure improvements requirements for power supply to the wells and the desalter
- Pipeline Routing – Once the well and plant sites are selected, the pipeline routing should be finalized, including a right of way acquisition study.
- CEQA – Once the previous items have been finalized, an environmental impact study should be conducted in accordance with CEQA guidelines. An initial study will determine if the potential environmental effects require a more substantial Environmental Impact Report (EIR). The feasibility report will need to be amended with any information necessary to support the CEQA study.
- Survey and Geotechnical Investigation – In support of the pipeline, well, and desalter facility designs, survey and geotechnical information should be developed.

- Pipelines - Aerial surveys at 1-ft contours overlaid on the aerial photos should be developed. Geotechnical borings at 1000-ft intervals along the pipeline alignment should be conducted.
- Wells and Desalter – Detailed site surveys for the proposed sites. Geotechnical investigations should be performed on each well site and the desalter site, complete with foundation design recommendations.

APPENDIX A – HYDRAULIC MODELING RESULTS



General

Title: AFT Fathom Model
Analysis run on: 5/30/2014 4:33:36 PM
Application version: AFT Fathom Version 8 (2013.10.24)
Input File: C:\Users\byallaly\Desktop\UWCD Raw and Product Water Pumping.fth
Scenario: Base Scenario/10,000 AFY_Design Water
Output File: C:\Users\byallaly\Desktop\UWCD Raw and Product Water Pumping_1.out

Execution Time= 0.38 seconds
Total Number Of Head/Pressure Iterations= 0
Total Number Of Flow Iterations= 2
Total Number Of Temperature Iterations= 0
Number Of Pipes= 95
Number Of Junctions= 93
Matrix Method= Gaussian Elimination

Pressure/Head Tolerance= 0.0001 relative change
Flow Rate Tolerance= 0.0001 relative change
Temperature Tolerance= 0.0001 relative change
Flow Relaxation= (Automatic)
Pressure Relaxation= (Automatic)

Constant Fluid Property Model
Fluid Database: AFT Standard
Fluid: Water at 1 atm
Max Fluid Temperature Data= 212 deg. F
Min Fluid Temperature Data= 32 deg. F
Temperature= 22 deg. C
Density= 62.29622 lbm/ft³
Viscosity= 2.30822 lbm/hr-ft
Vapor Pressure= 0.38264 psia
Viscosity Model= Newtonian
Apply laminar and non-Newtonian correction to: Pipe Fittings & Losses, Junction K factors, Junction Special Losses, Junction Polynomials
Corrections applied to the following junctions: Branch, Reservoir, Assigned Flow, Assigned Pressure, Area Change, Bend, Tee or Wye, Control Valve, Spray Discharge, Relief Valve

Ambient Pressure (constant)= 1 atm
Gravitational Acceleration= 1 g
Turbulent Flow Above Reynolds Number= 4000
Laminar Flow Below Reynolds Number= 2300
Total Inflow= 13,898 gal/min
Total Outflow= 13,898 gal/min
Maximum Static Pressure is 91.50 psia at Pipe 33 Inlet
Minimum Static Pressure is 14.67 psia at Pipe 104 Inlet
Fixed Energy Cost = 0.0125 U.S. Dollars per kW-hr
The following cost databases were used:
Total of All Model Costs = 0 U.S. Dollars

Warnings

No Warnings

Pump Summary

Jct	Name	Vol. Flow (gal/min)	dH (feet)	Overall Efficiency (Percent)	Speed (Percent)	Overall Power (hp)	NPSHA (feet)	NPSHR (feet)	Energy Cost (U.S. Dollars)
25	Well No. 1	1,931	225.6	100.0	N/A	109.93	39.08	N/A	0
31	Well No. 2	1,931	199.6	100.0	N/A	97.26	40.08	N/A	0
37	Well No. 3	1,931	188.4	100.0	N/A	91.78	40.08	N/A	0
X43	Well No. 4	0	N/A	N/A	0	N/A	N/A	N/A	0
X48	Well No. 5	0	N/A	N/A	0	N/A	N/A	N/A	0
55	Well No. 6	1,931	194.2	100.0	N/A	94.60	42.08	N/A	0
X62	Well No. 7	0	N/A	N/A	0	N/A	N/A	N/A	0
X67	Well No. 8	0	N/A	N/A	0	N/A	N/A	N/A	0
X72	Well No. 9	0	N/A	N/A	0	N/A	N/A	N/A	0
X77	Well No. 10	0	N/A	N/A	0	N/A	N/A	N/A	0
X82	Well No. 11	0	N/A	N/A	0	N/A	N/A	N/A	0
X87	Well No. 12	0	N/A	N/A	0	N/A	N/A	N/A	0
97	Pump	3,087	154.5	100.0	N/A	120.38	40.17	N/A	0
100	Pump	3,087	155.0	100.0	N/A	120.71	40.14	N/A	0
X103	Pump	0	N/A	N/A	0	N/A	N/A	N/A	0
X107	Pump	0	N/A	N/A	0	N/A	N/A	N/A	0
X110	Pump	0	N/A	N/A	0	N/A	N/A	N/A	0

Valve Summary

Jct	Name	Valve Type	Vol. Flow (gal/min)	dH (feet)	P Static In (psia)	Cv	K	Valve State
27	Valve	REGULAR	1,931	0.6831	86.65	3,550	0.8328	Open
33	Valve	REGULAR	1,931	0.6831	75.83	3,550	0.8328	Open
39	Valve	REGULAR	1,931	0.6831	70.96	3,550	0.8328	Open
45	Valve	REGULAR	0	N/A	66.01	N/A	N/A	Open
50	Valve	REGULAR	0	N/A	66.70	N/A	N/A	Open
57	Valve	REGULAR	1,931	0.6831	74.33	3,550	0.8328	Open
64	Valve	REGULAR	0	N/A	65.56	N/A	N/A	Open
69	Valve	REGULAR	0	N/A	66.86	N/A	N/A	Open
74	Valve	REGULAR	0	N/A	66.43	N/A	N/A	Open
79	Valve	REGULAR	0	N/A	68.16	N/A	N/A	Open
84	Valve	REGULAR	0	N/A	66.86	N/A	N/A	Open
89	Valve	REGULAR	0	N/A	66.86	N/A	N/A	Open
26	Check Valve	CHECK	1,931	0.3842	86.84	4,733	0.4684	Open
32	Check Valve	CHECK	1,931	0.3842	76.03	4,733	0.4684	Open
38	Check Valve	CHECK	1,931	0.3842	71.15	4,733	0.4684	Open
44	Check Valve	CHECK	0	N/A	66.01	N/A	N/A	Open
49	Check Valve	CHECK	0	N/A	66.70	N/A	N/A	Open
56	Check Valve	CHECK	1,931	0.3842	74.52	4,733	0.4684	Open
63	Check Valve	CHECK	0	N/A	65.56	N/A	N/A	Open
68	Check Valve	CHECK	0	N/A	66.86	N/A	N/A	Open
73	Check Valve	CHECK	0	N/A	66.43	N/A	N/A	Open
78	Check Valve	CHECK	0	N/A	68.16	N/A	N/A	Open
83	Check Valve	CHECK	0	N/A	66.86	N/A	N/A	Open
88	Check Valve	CHECK	0	N/A	66.86	N/A	N/A	Open

Reservoir Summary

Jct	Name	Type	Liq. Height (feet)	Liq. Elevation (feet)	Surface Pressure (psia)	Liquid Volume (feet3)	Liquid Mass (lbm)	Net Vol. Flow (gal/min)	Net Mass Flow (lbm/sec)
24	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
30	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
36	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
42	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
47	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
54	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
61	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
66	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
71	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
76	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
81	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
86	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
96	Reservoir	Infinite	N/A	20.00	14.70	N/A	N/A	-6,174	-856.9

Pipe Output Table

Pipe	Name	Vol. Flow Rate (MGD)	Velocity (feet/sec)	dH (feet)
4	Pipe	8.891	4.3786	44.8662936
X5	Pipe	0.000	0.0000	0.0000000
6	Pipe	8.891	4.3786	20.6001902
29	Pipe	2.781	7.2650	0.0012805
30	Pipe	2.781	7.2650	1.0397569
31	Pipe	2.781	7.2650	0.0640244
32	Pipe	2.781	7.2650	0.1920731
33	Well 1 to Well 2 - 12" HDPE DR13.5	2.781	6.8286	27.0354544
34	Pipe	2.781	7.2650	0.0012805
35	Pipe	2.781	7.2650	1.0397569
36	Pipe	2.781	7.2650	0.0640244
37	Pipe	2.781	7.2650	0.1920731
38	Pipe	2.781	6.8286	0.7560194
39	Well 2 to Well 3 - 20" HDPE DR13.5	5.561	5.5499	11.3071764
40	Pipe	2.781	7.2650	0.0012805
41	Pipe	2.781	7.2650	1.0397569
42	Pipe	2.781	7.2650	0.0640244
43	Pipe	2.781	7.2650	0.1920731
44	Pipe	2.781	6.8286	0.7560196
45	Pipe	0.000	0.0000	0.0000000
46	Pipe	0.000	0.0000	0.0000000
47	Pipe	0.000	0.0000	0.0000000
48	Pipe	0.000	0.0000	0.0000000
49	Pipe	0.000	0.0000	0.0000000
50	Well 3 to Well 4 - 24" HDPE DR13.5	8.342	5.7817	9.8380571
51	Pipe	0.000	0.0000	0.0000000
52	Pipe	0.000	0.0000	0.0000000
53	Pipe	0.000	0.0000	0.0000000
54	Pipe	0.000	0.0000	0.0000000
55	Pipe	0.000	0.0000	0.0000000
56	Well 4 to Well 5/6 Blend - 30" HDPE DR13.5	8.342	3.7002	1.6723998
57	Pipe	2.781	7.2650	0.0012807
58	Pipe	2.781	7.2650	1.0397569
59	Pipe	2.781	7.2650	0.0640244
60	Pipe	2.781	7.2650	0.1920731
61	Pipe	2.781	6.8286	0.7560153
62	Well 6 to Well 5 - 12" HDPE DR13.5	2.781	6.8286	17.6770025

Pipe	Name	Vol. Flow Rate (MGD)	Velocity (feet/sec)	dH (feet)
63	Well 11 to Well 9 Blend - 20" HDPE DR13.5	2.781	2.2176	0.3103212
64	North Wells to Desalter - 36" HDPE DR13.5	11.123	3.4261	1.2160755
65	Pipe	0.000	0.0000	0.0000000
66	Pipe	0.000	0.0000	0.0000000
67	Pipe	0.000	0.0000	0.0000000
68	Pipe	0.000	0.0000	0.0000000
70	Pipe	0.000	0.0000	0.0000000
71	Pipe	0.000	0.0000	0.0000000
72	Pipe	0.000	0.0000	0.0000000
73	Pipe	0.000	0.0000	0.0000000
75	Pipe	0.000	0.0000	0.0000000
76	Pipe	0.000	0.0000	0.0000000
77	Pipe	0.000	0.0000	0.0000000
78	Pipe	0.000	0.0000	0.0000000
79	Pipe	0.000	0.0000	0.0000000
80	Pipe	0.000	0.0000	0.0000000
81	Pipe	0.000	0.0000	0.0000000
82	Pipe	0.000	0.0000	0.0000000
83	Pipe	0.000	0.0000	0.0000000
84	Pipe	0.000	0.0000	0.0000000
85	Pipe	0.000	0.0000	0.0000000
86	Pipe	0.000	0.0000	0.0000000
87	Pipe	0.000	0.0000	0.0000000
88	Pipe	0.000	0.0000	0.0000000
89	Pipe	0.000	0.0000	0.0000000
90	Pipe	0.000	0.0000	0.0000000
91	Pipe	0.000	0.0000	0.0000000
92	Pipe	0.000	0.0000	0.0000000
93	Pipe	0.000	0.0000	0.0000000
94	Pipe	0.000	0.0000	0.0000000
95	Well 7/8 to Well 9 - 20" HDPE DR13.5	0.000	0.0000	0.0000000
96	Well 9 to Well 10 - 24" HDPE DR13.5	0.000	0.0000	0.0000000
98	Well 12 to Desalter - 36" HDPE DR13.5	0.000	0.0000	0.0000000
100	Well 10/11 to Well 12 - 36" HDPE DR13.5	0.000	0.0000	0.0000000
101	Well 7 to Well 8 Blend - 12" HDPE DR13.5	0.000	0.0000	0.0000000
102	Well 7 to Well 8 Blend - 12" HDPE DR13.5	0.000	0.0000	0.0000000
103	Well 10 to Well 11 - 30" HDPE DR13.5	0.000	0.0000	0.0000000
104	Pipe	8.891	1.9460	0.2057422
105	Pipe	4.445	3.8921	0.3487453
106	Pipe	4.445	4.9259	1.1992354

Pipe	Name	Vol. Flow Rate (MGD)	Velocity (feet/sec)	dH (feet)
107	Pipe	0.000	0.0000	0.0000000
108	Pipe	4.445	0.9730	0.0009715
109	Pipe	4.445	3.8921	0.3487453
110	Pipe	4.445	4.9259	1.1992354
111	Pipe	4.445	0.9730	0.0009715
112	Pipe	0.000	0.0000	0.0000000
113	Pipe	0.000	0.0000	0.0000000
114	Pipe	0.000	0.0000	0.0000000
115	Pipe	8.891	1.9460	0.0035070
116	Pipe	0.000	0.0000	0.0000000
117	Pipe	0.000	0.0000	0.0000000
118	Pipe	0.000	0.0000	0.0000000
119	Pipe	0.000	0.0000	0.0000000
120	Pipe	8.891	1.9460	0.0035069
121	Pipe	0.000	0.0000	0.0000000
122	Pipe	8.891	1.9460	0.0035069
123	Pipe	0.000	0.0000	0.0000000
124	Pipe	0.000	0.0000	0.0000000

All Junction Table

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
5	PTP Connection	0	0.0	0.0000	0.0000
6	PVCWD Connection	6,174	856.9	0.0000	0.0000
7	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
24	Reservoir	1,931	268.0	0.0000	0.0000
25	Well No. 1	1,931	268.0	0.0000	-225.6302
26	Check Valve	1,931	268.0	0.4684	0.3842
27	Valve	1,931	268.0	0.8328	0.6831
28	Branch	1,931	268.0	0.0000	0.0000
29	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
30	Reservoir	1,931	268.0	0.0000	0.0000
31	Well No. 2	1,931	268.0	0.0000	-199.6296
32	Check Valve	1,931	268.0	0.4684	0.3842
33	Valve	1,931	268.0	0.8328	0.6831
34	Branch	1,931	268.0	0.0000	0.0000
35	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
36	Reservoir	1,931	268.0	0.0000	0.0000
37	Well No. 3	1,931	268.0	0.0000	-188.3640
38	Check Valve	1,931	268.0	0.4684	0.3842
39	Valve	1,931	268.0	0.8328	0.6831
40	Branch	1,931	268.0	0.0000	0.0000
41	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
42	Reservoir	0	0.0	0.0000	0.0000
X43	Well No. 4	0	0.0	0.0000	N/A
44	Check Valve	0	0.0	0.0000	0.0000
45	Valve	0	0.0	0.0000	0.0000
46	Branch	0	0.0	0.0000	0.0000
47	Reservoir	0	0.0	0.0000	0.0000
X48	Well No. 5	0	0.0	0.0000	N/A
49	Check Valve	0	0.0	0.0000	0.0000
50	Valve	0	0.0	0.0000	0.0000
51	Branch	0	0.0	0.0000	0.0000
52	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
53	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
54	Reservoir	1,931	268.0	0.0000	0.0000
55	Well No. 6	1,931	268.0	0.0000	-194.1538
56	Check Valve	1,931	268.0	0.4684	0.3842
57	Valve	1,931	268.0	0.8328	0.6831

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
58	Branch	1,931	268.0	0.0000	0.0000
59	Bend	1,931	268.0	0.1908	0.1382
60	Pressure Entering Desalter	N/A	N/A	0.0000	0.0000
61	Reservoir	0	0.0	0.0000	0.0000
X62	Well No. 7	0	0.0	0.0000	N/A
63	Check Valve	0	0.0	0.0000	0.0000
64	Valve	0	0.0	0.0000	0.0000
65	Branch	0	0.0	0.0000	0.0000
66	Reservoir	0	0.0	0.0000	0.0000
X67	Well No. 8	0	0.0	0.0000	N/A
68	Check Valve	0	0.0	0.0000	0.0000
69	Valve	0	0.0	0.0000	0.0000
70	Branch	0	0.0	0.0000	0.0000
71	Reservoir	0	0.0	0.0000	0.0000
X72	Well No. 9	0	0.0	0.0000	N/A
73	Check Valve	0	0.0	0.0000	0.0000
74	Valve	0	0.0	0.0000	0.0000
75	Branch	0	0.0	0.0000	0.0000
76	Reservoir	0	0.0	0.0000	0.0000
X77	Well No. 10	0	0.0	0.0000	N/A
78	Check Valve	0	0.0	0.0000	0.0000
79	Valve	0	0.0	0.0000	0.0000
80	Branch	0	0.0	0.0000	0.0000
81	Reservoir	0	0.0	0.0000	0.0000
X82	Well No. 11	0	0.0	0.0000	N/A
83	Check Valve	0	0.0	0.0000	0.0000
84	Valve	0	0.0	0.0000	0.0000
85	Branch	0	0.0	0.0000	0.0000
86	Reservoir	0	0.0	0.0000	0.0000
X87	Well No. 12	0	0.0	0.0000	N/A
88	Check Valve	0	0.0	0.0000	0.0000
89	Valve	0	0.0	0.0000	0.0000
90	Branch	0	0.0	0.0000	0.0000
91	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
92	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
93	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
94	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
95	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
96	Reservoir	6,174	856.9	0.0000	0.0000
97	Pump	3,087	428.5	0.0000	-154.5463

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
98	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
99	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
100	Pump	3,087	428.5	0.0000	-154.9698
101	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
102	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
X103	Pump	0	0.0	0.0000	N/A
104	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
105	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
106	Dead End	0	0.0	0.0000	0.0000
X107	Pump	0	0.0	0.0000	N/A
108	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
109	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
X110	Pump	0	0.0	0.0000	N/A
111	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
112	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
113	Dead End	0	0.0	0.0000	0.0000

General

Title: AFT Fathom Model
Analysis run on: 5/30/2014 4:36:08 PM
Application version: AFT Fathom Version 8 (2013.10.24)
Input File: C:\Users\byallaly\Desktop\UWCD Raw and Product Water Pumping.fth
Scenario: Base Scenario/20,000 AFY_Design Water
Output File: C:\Users\byallaly\Desktop\UWCD Raw and Product Water Pumping_2.out

Execution Time= 0.11 seconds
Total Number Of Head/Pressure Iterations= 0
Total Number Of Flow Iterations= 2
Total Number Of Temperature Iterations= 0
Number Of Pipes= 95
Number Of Junctions= 93
Matrix Method= Gaussian Elimination

Pressure/Head Tolerance= 0.0001 relative change
Flow Rate Tolerance= 0.0001 relative change
Temperature Tolerance= 0.0001 relative change
Flow Relaxation= (Automatic)
Pressure Relaxation= (Automatic)

Constant Fluid Property Model
Fluid Database: AFT Standard
Fluid: Water at 1 atm
Max Fluid Temperature Data= 212 deg. F
Min Fluid Temperature Data= 32 deg. F
Temperature= 22 deg. C
Density= 62.29622 lbm/ft³
Viscosity= 2.30822 lbm/hr-ft
Vapor Pressure= 0.38264 psia
Viscosity Model= Newtonian
Apply laminar and non-Newtonian correction to: Pipe Fittings & Losses, Junction K factors, Junction Special Losses, Junction Polynomials
Corrections applied to the following junctions: Branch, Reservoir, Assigned Flow, Assigned Pressure, Area Change, Bend, Tee or Wye, Control Valve, Spray Discharge, Relief Valve

Ambient Pressure (constant)= 1 atm
Gravitational Acceleration= 1 g
Turbulent Flow Above Reynolds Number= 4000
Laminar Flow Below Reynolds Number= 2300
Total Inflow= 27,796 gal/min
Total Outflow= 27,796 gal/min
Maximum Static Pressure is 91.50 psia at Pipe 33 Inlet
Minimum Static Pressure is 14.59 psia at Pipe 104 Inlet
Fixed Energy Cost = 0.0125 U.S. Dollars per kW-hr
The following cost databases were used:
Total of All Model Costs = 0 U.S. Dollars

Warnings

No Warnings

Pump Summary

Jct	Name	Vol. Flow (gal/min)	dH (feet)	Overall Efficiency (Percent)	Speed (Percent)	Overall Power (hp)	NPSHA (feet)	NPSHR (feet)	Energy Cost (U.S. Dollars)
25	Well No. 1	1,931	225.6	100.0	N/A	109.93	39.08	N/A	0
31	Well No. 2	1,931	199.6	100.0	N/A	97.26	40.08	N/A	0
37	Well No. 3	1,931	188.4	100.0	N/A	91.78	40.08	N/A	0
X43	Well No. 4	0	N/A	N/A	0	N/A	N/A	N/A	0
X48	Well No. 5	0	N/A	N/A	0	N/A	N/A	N/A	0
55	Well No. 6	1,931	194.2	100.0	N/A	94.60	42.08	N/A	0
62	Well No. 7	1,931	210.8	100.0	N/A	102.70	42.08	N/A	0
67	Well No. 8	1,931	212.6	100.0	N/A	103.59	45.08	N/A	0
72	Well No. 9	1,931	191.0	100.0	N/A	93.07	44.08	N/A	0
77	Well No. 10	1,931	179.2	100.0	N/A	87.31	48.08	N/A	0
X82	Well No. 11	0	N/A	N/A	0	N/A	N/A	N/A	0
X87	Well No. 12	0	N/A	N/A	0	N/A	N/A	N/A	0
97	Pump	3,087	123.3	100.0	N/A	96.01	39.27	N/A	0
100	Pump	3,087	123.7	100.0	N/A	96.39	39.24	N/A	0
103	Pump	3,087	123.2	100.0	N/A	95.92	39.53	N/A	0
107	Pump	3,087	123.8	100.0	N/A	96.46	39.22	N/A	0
X110	Pump	0	N/A	N/A	0	N/A	N/A	N/A	0

Valve Summary

Jct	Name	Valve Type	Vol. Flow (gal/min)	dH (feet)	P Static In (psia)	Cv	K	Valve State
27	Valve	REGULAR	1,931	0.6831	86.65	3,550	0.8328	Open
33	Valve	REGULAR	1,931	0.6831	75.83	3,550	0.8328	Open
39	Valve	REGULAR	1,931	0.6831	70.96	3,550	0.8328	Open
45	Valve	REGULAR	0	N/A	66.01	N/A	N/A	Open
50	Valve	REGULAR	0	N/A	66.70	N/A	N/A	Open
57	Valve	REGULAR	1,931	0.6831	74.33	3,550	0.8328	Open
64	Valve	REGULAR	1,931	0.6831	81.53	3,550	0.8328	Open
69	Valve	REGULAR	1,931	0.6831	83.61	3,550	0.8328	Open
74	Valve	REGULAR	1,931	0.6831	73.84	3,550	0.8328	Open
79	Valve	REGULAR	1,931	0.6831	70.45	3,550	0.8328	Open
84	Valve	REGULAR	0	N/A	68.47	N/A	N/A	Open
89	Valve	REGULAR	0	N/A	67.45	N/A	N/A	Open
26	Check Valve	CHECK	1,931	0.3842	86.84	4,733	0.4684	Open
32	Check Valve	CHECK	1,931	0.3842	76.03	4,733	0.4684	Open
38	Check Valve	CHECK	1,931	0.3842	71.15	4,733	0.4684	Open
44	Check Valve	CHECK	0	N/A	66.01	N/A	N/A	Open
49	Check Valve	CHECK	0	N/A	66.70	N/A	N/A	Open
56	Check Valve	CHECK	1,931	0.3842	74.52	4,733	0.4684	Open
63	Check Valve	CHECK	1,931	0.3842	81.72	4,733	0.4684	Open
68	Check Valve	CHECK	1,931	0.3842	83.81	4,733	0.4684	Open
73	Check Valve	CHECK	1,931	0.3842	74.03	4,733	0.4684	Open
78	Check Valve	CHECK	1,931	0.3842	70.65	4,733	0.4684	Open
83	Check Valve	CHECK	0	N/A	68.47	N/A	N/A	Open
88	Check Valve	CHECK	0	N/A	67.45	N/A	N/A	Open

Reservoir Summary

Jct	Name	Type	Liq. Height (feet)	Liq. Elevation (feet)	Surface Pressure (psia)	Liquid Volume (feet3)	Liquid Mass (lbm)	Net Vol. Flow (gal/min)	Net Mass Flow (lbm/sec)
24	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
30	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
36	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
42	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
47	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
54	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
61	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
66	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
71	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
76	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,931	-268.0
81	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
86	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
96	Reservoir	Infinite	N/A	20.00	14.70	N/A	N/A	-12,348	-1,713.9

Pipe Output Table

Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
4	Pipe	12,348	3.8921	22.7969367
X5	Pipe	0	0.0000	0.0000000
6	Pipe	12,348	3.8921	10.5273357
29	Pipe	1,931	7.2650	0.0012805
30	Pipe	1,931	7.2650	1.0397569
31	Pipe	1,931	7.2650	0.0640244
32	Pipe	1,931	7.2650	0.1920731
33	Well 1 to Well 2 - 12" HDPE DR13.5	1,931	6.8286	27.0354544
34	Pipe	1,931	7.2650	0.0012805
35	Pipe	1,931	7.2650	1.0397569
36	Pipe	1,931	7.2650	0.0640244
37	Pipe	1,931	7.2650	0.1920731
38	Pipe	1,931	6.8286	0.7560194
39	Well 2 to Well 3 - 20" HDPE DR13.5	3,862	5.5499	11.3071764
40	Pipe	1,931	7.2650	0.0012805
41	Pipe	1,931	7.2650	1.0397569
42	Pipe	1,931	7.2650	0.0640244
43	Pipe	1,931	7.2650	0.1920731
44	Pipe	1,931	6.8286	0.7560196
45	Pipe	0	0.0000	0.0000000
46	Pipe	0	0.0000	0.0000000
47	Pipe	0	0.0000	0.0000000
48	Pipe	0	0.0000	0.0000000
49	Pipe	0	0.0000	0.0000000
50	Well 3 to Well 4 - 24" HDPE DR13.5	5,793	5.7817	9.8380571
51	Pipe	0	0.0000	0.0000000
52	Pipe	0	0.0000	0.0000000
53	Pipe	0	0.0000	0.0000000
54	Pipe	0	0.0000	0.0000000
55	Pipe	0	0.0000	0.0000000
56	Well 4 to Well 5/6 Blend - 30" HDPE DR13.5	5,793	3.7002	1.6723998
57	Pipe	1,931	7.2650	0.0012807
58	Pipe	1,931	7.2650	1.0397569
59	Pipe	1,931	7.2650	0.0640244
60	Pipe	1,931	7.2650	0.1920731
61	Pipe	1,931	6.8286	0.7560153
62	Well 6 to Well 5 - 12" HDPE DR13.5	1,931	6.8286	17.6770025

Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
63	Well 11 to Well 9 Blend - 20" HDPE DR13.5	1,931	2.2176	0.3103212
64	North Wells to Desalter - 36" HDPE DR13.5	7,724	3.4261	1.2160755
65	Pipe	1,931	7.2650	0.0012807
66	Pipe	1,931	7.2650	1.0397569
67	Pipe	1,931	7.2650	0.0640244
68	Pipe	1,931	7.2650	0.1920731
70	Pipe	1,931	7.2650	0.0012804
71	Pipe	1,931	7.2650	1.0397569
72	Pipe	1,931	7.2650	0.0640244
73	Pipe	1,931	7.2650	0.1920731
75	Pipe	1,931	7.2650	0.0012809
76	Pipe	1,931	7.2650	1.0397569
77	Pipe	1,931	7.2650	0.0640244
78	Pipe	1,931	7.2650	0.1920731
79	Pipe	1,931	6.8286	0.7560195
80	Pipe	1,931	7.2650	0.0012801
81	Pipe	1,931	7.2650	1.0397569
82	Pipe	1,931	7.2650	0.0640244
83	Pipe	1,931	7.2650	0.1920731
84	Pipe	1,931	6.8286	0.7560194
85	Pipe	0	0.0000	0.0000000
86	Pipe	0	0.0000	0.0000000
87	Pipe	0	0.0000	0.0000000
88	Pipe	0	0.0000	0.0000000
89	Pipe	0	0.0000	0.0000000
90	Pipe	0	0.0000	0.0000000
91	Pipe	0	0.0000	0.0000000
92	Pipe	0	0.0000	0.0000000
93	Pipe	0	0.0000	0.0000000
94	Pipe	0	0.0000	0.0000000
95	Well 7/8 to Well 9 - 20" HDPE DR13.5	3,862	5.5506	6.8830311
96	Well 9 to Well 10 - 24" HDPE DR13.5	5,793	5.7817	11.5947870
98	Well 12 to Desalter - 36" HDPE DR13.5	7,724	3.4261	1.3554621
100	Well 10/11 to Well 12 - 36" HDPE DR13.5	7,724	3.4261	2.3635106
101	Well 7 to Well 8 Blend - 12" HDPE DR13.5	1,931	6.8286	15.7225200
102	Well 7 to Well 8 Blend - 12" HDPE DR13.5	1,931	6.8286	13.9028265
103	Well 10 to Well 11 - 30" HDPE DR13.5	7,724	4.9337	0.1048668
104	Pipe	12,348	3.8921	0.8092790
105	Pipe	3,087	3.8921	0.3487453
106	Pipe	3,087	4.9259	1.1992354

Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
107	Pipe	0	0.0000	0.0000000
108	Pipe	9,261	2.9191	0.0074305
109	Pipe	3,087	3.8921	0.3487453
110	Pipe	3,087	4.9259	1.1992354
111	Pipe	3,087	0.9730	0.0009715
112	Pipe	6,174	1.9460	0.0035069
113	Pipe	3,087	3.8921	0.3487453
114	Pipe	3,087	4.9259	1.1992354
115	Pipe	6,174	1.9460	0.0035069
116	Pipe	0	0.0000	0.0000000
117	Pipe	3,087	0.9730	0.0009715
118	Pipe	3,087	3.8921	0.3487453
119	Pipe	3,087	4.9259	1.1992354
120	Pipe	9,261	2.9191	0.0074305
121	Pipe	0	0.0000	0.0000000
122	Pipe	12,348	3.8921	0.0126588
123	Pipe	0	0.0000	0.0000000
124	Pipe	0	0.0000	0.0000000

All Junction Table

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
5	PTP Connection	0	0.0	0.0000	0.0000
6	PVCWD Connection	12,348	1,713.9	0.0000	0.0000
7	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
24	Reservoir	1,931	268.0	0.0000	0.0000
25	Well No. 1	1,931	268.0	0.0000	-225.6302
26	Check Valve	1,931	268.0	0.4684	0.3842
27	Valve	1,931	268.0	0.8328	0.6831
28	Branch	1,931	268.0	0.0000	0.0000
29	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
30	Reservoir	1,931	268.0	0.0000	0.0000
31	Well No. 2	1,931	268.0	0.0000	-199.6296
32	Check Valve	1,931	268.0	0.4684	0.3842
33	Valve	1,931	268.0	0.8328	0.6831
34	Branch	1,931	268.0	0.0000	0.0000
35	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
36	Reservoir	1,931	268.0	0.0000	0.0000
37	Well No. 3	1,931	268.0	0.0000	-188.3640
38	Check Valve	1,931	268.0	0.4684	0.3842
39	Valve	1,931	268.0	0.8328	0.6831
40	Branch	1,931	268.0	0.0000	0.0000
41	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
42	Reservoir	0	0.0	0.0000	0.0000
X43	Well No. 4	0	0.0	0.0000	N/A
44	Check Valve	0	0.0	0.0000	0.0000
45	Valve	0	0.0	0.0000	0.0000
46	Branch	0	0.0	0.0000	0.0000
47	Reservoir	0	0.0	0.0000	0.0000
X48	Well No. 5	0	0.0	0.0000	N/A
49	Check Valve	0	0.0	0.0000	0.0000
50	Valve	0	0.0	0.0000	0.0000
51	Branch	0	0.0	0.0000	0.0000
52	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
53	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
54	Reservoir	1,931	268.0	0.0000	0.0000
55	Well No. 6	1,931	268.0	0.0000	-194.1538
56	Check Valve	1,931	268.0	0.4684	0.3842
57	Valve	1,931	268.0	0.8328	0.6831

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
58	Branch	1,931	268.0	0.0000	0.0000
59	Bend	1,931	268.0	0.1908	0.1382
60	Pressure Entering Desalter	N/A	N/A	0.0000	0.0000
61	Reservoir	1,931	268.0	0.0000	0.0000
62	Well No. 7	1,931	268.0	0.0000	-210.7906
63	Check Valve	1,931	268.0	0.4684	0.3842
64	Valve	1,931	268.0	0.8328	0.6831
65	Branch	1,931	268.0	0.0000	0.0000
66	Reservoir	1,931	268.0	0.0000	0.0000
67	Well No. 8	1,931	268.0	0.0000	-212.6103
68	Check Valve	1,931	268.0	0.4684	0.3842
69	Valve	1,931	268.0	0.8328	0.6831
70	Branch	1,931	268.0	0.0000	0.0000
71	Reservoir	1,931	268.0	0.0000	0.0000
72	Well No. 9	1,931	268.0	0.0000	-191.0212
73	Check Valve	1,931	268.0	0.4684	0.3842
74	Valve	1,931	268.0	0.8328	0.6831
75	Branch	1,931	268.0	0.0000	0.0000
76	Reservoir	1,931	268.0	0.0000	0.0000
77	Well No. 10	1,931	268.0	0.0000	-179.1985
78	Check Valve	1,931	268.0	0.4684	0.3842
79	Valve	1,931	268.0	0.8328	0.6831
80	Branch	1,931	268.0	0.0000	0.0000
81	Reservoir	0	0.0	0.0000	0.0000
X82	Well No. 11	0	0.0	0.0000	N/A
83	Check Valve	0	0.0	0.0000	0.0000
84	Valve	0	0.0	0.0000	0.0000
85	Branch	0	0.0	0.0000	0.0000
86	Reservoir	0	0.0	0.0000	0.0000
X87	Well No. 12	0	0.0	0.0000	N/A
88	Check Valve	0	0.0	0.0000	0.0000
89	Valve	0	0.0	0.0000	0.0000
90	Branch	0	0.0	0.0000	0.0000
91	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
92	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
93	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
94	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
95	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
96	Reservoir	12,348	1,713.9	0.0000	0.0000
97	Pump	3,087	428.5	0.0000	-123.2630

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
98	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
99	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
100	Pump	3,087	428.5	0.0000	-123.7482
101	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
102	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
103	Pump	3,087	428.5	0.0000	-123.1512
104	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
105	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
106	Dead End	0	0.0	0.0000	0.0000
107	Pump	3,087	428.5	0.0000	-123.8470
108	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
109	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
X110	Pump	0	0.0	0.0000	N/A
111	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
112	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
113	Dead End	0	0.0	0.0000	0.0000

General

Title: AFT Fathom Model
Analysis run on: 5/30/2014 4:38:47 PM
Application version: AFT Fathom Version 8 (2013.10.24)
Input File: C:\Users\byallaly\Desktop\UWCD Raw and Product Water Pumping.fth
Scenario: Base Scenario/10,000 AFY_Worst Water
Output File: C:\Users\byallaly\Desktop\UWCD Raw and Product Water Pumping_3.out

Execution Time= 0.11 seconds
Total Number Of Head/Pressure Iterations= 0
Total Number Of Flow Iterations= 2
Total Number Of Temperature Iterations= 0
Number Of Pipes= 95
Number Of Junctions= 93
Matrix Method= Gaussian Elimination

Pressure/Head Tolerance= 0.0001 relative change
Flow Rate Tolerance= 0.0001 relative change
Temperature Tolerance= 0.0001 relative change
Flow Relaxation= (Automatic)
Pressure Relaxation= (Automatic)

Constant Fluid Property Model
Fluid Database: AFT Standard
Fluid: Water at 1 atm
Max Fluid Temperature Data= 212 deg. F
Min Fluid Temperature Data= 32 deg. F
Temperature= 22 deg. C
Density= 62.29622 lbm/ft³
Viscosity= 2.30822 lbm/hr-ft
Vapor Pressure= 0.38264 psia
Viscosity Model= Newtonian
Apply laminar and non-Newtonian correction to: Pipe Fittings & Losses, Junction K factors, Junction Special Losses, Junction Polynomials
Corrections applied to the following junctions: Branch, Reservoir, Assigned Flow, Assigned Pressure, Area Change, Bend, Tee or Wye, Control Valve, Spray Discharge, Relief Valve

Ambient Pressure (constant)= 1 atm
Gravitational Acceleration= 1 g
Turbulent Flow Above Reynolds Number= 4000
Laminar Flow Below Reynolds Number= 2300
Total Inflow= 14,759 gal/min
Total Outflow= 14,759 gal/min
Maximum Static Pressure is 87.94 psia at Pipe 33 Inlet
Minimum Static Pressure is 14.67 psia at Pipe 104 Inlet
Fixed Energy Cost = 0.0125 U.S. Dollars per kW-hr
The following cost databases were used:
Total of All Model Costs = 0 U.S. Dollars

Warnings

No Warnings

Pump Summary

Jct	Name	Vol. Flow (gal/min)	dH (feet)	Overall Efficiency (Percent)	Speed (Percent)	Overall Power (hp)	NPSHA (feet)	NPSHR (feet)	Energy Cost (U.S. Dollars)
25	Well No. 1	1,717	216.8	100.0	N/A	93.90	39.08	N/A	0
31	Well No. 2	1,717	195.8	100.0	N/A	84.81	40.08	N/A	0
37	Well No. 3	1,717	186.7	100.0	N/A	80.87	40.08	N/A	0
43	Well No. 4	1,717	178.6	100.0	N/A	77.36	42.08	N/A	0
X48	Well No. 5	0	N/A	N/A	0	N/A	N/A	N/A	0
55	Well No. 6	1,717	190.3	100.0	N/A	82.45	42.08	N/A	0
X62	Well No. 7	0	N/A	N/A	0	N/A	N/A	N/A	0
X67	Well No. 8	0	N/A	N/A	0	N/A	N/A	N/A	0
X72	Well No. 9	0	N/A	N/A	0	N/A	N/A	N/A	0
X77	Well No. 10	0	N/A	N/A	0	N/A	N/A	N/A	0
X82	Well No. 11	0	N/A	N/A	0	N/A	N/A	N/A	0
X87	Well No. 12	0	N/A	N/A	0	N/A	N/A	N/A	0
97	Pump	3,087	154.5	100.0	N/A	120.38	40.17	N/A	0
100	Pump	3,087	155.0	100.0	N/A	120.71	40.14	N/A	0
X103	Pump	0	N/A	N/A	0	N/A	N/A	N/A	0
X107	Pump	0	N/A	N/A	0	N/A	N/A	N/A	0
X110	Pump	0	N/A	N/A	0	N/A	N/A	N/A	0

Valve Summary

Jct	Name	Valve Type	Vol. Flow (gal/min)	dH (feet)	P Static In (psia)	Cv	K	Valve State
27	Valve	REGULAR	1,717	0.5401	83.02	3,550	0.8328	Open
33	Valve	REGULAR	1,717	0.5401	74.37	3,550	0.8328	Open
39	Valve	REGULAR	1,717	0.5401	70.44	3,550	0.8328	Open
45	Valve	REGULAR	1,717	0.5401	66.93	3,550	0.8328	Open
50	Valve	REGULAR	0	N/A	66.80	N/A	N/A	Open
57	Valve	REGULAR	1,717	0.5401	72.87	3,550	0.8328	Open
64	Valve	REGULAR	0	N/A	65.56	N/A	N/A	Open
69	Valve	REGULAR	0	N/A	66.86	N/A	N/A	Open
74	Valve	REGULAR	0	N/A	66.43	N/A	N/A	Open
79	Valve	REGULAR	0	N/A	68.16	N/A	N/A	Open
84	Valve	REGULAR	0	N/A	66.86	N/A	N/A	Open
89	Valve	REGULAR	0	N/A	66.86	N/A	N/A	Open
26	Check Valve	CHECK	1,717	0.2962	83.17	4,793	0.4568	Open
32	Check Valve	CHECK	1,717	0.2962	74.52	4,793	0.4568	Open
38	Check Valve	CHECK	1,717	0.2962	70.59	4,793	0.4568	Open
44	Check Valve	CHECK	1,717	0.2962	67.08	4,793	0.4568	Open
49	Check Valve	CHECK	0	N/A	66.80	N/A	N/A	Open
56	Check Valve	CHECK	1,717	0.2962	73.02	4,793	0.4568	Open
63	Check Valve	CHECK	0	N/A	65.56	N/A	N/A	Open
68	Check Valve	CHECK	0	N/A	66.86	N/A	N/A	Open
73	Check Valve	CHECK	0	N/A	66.43	N/A	N/A	Open
78	Check Valve	CHECK	0	N/A	68.16	N/A	N/A	Open
83	Check Valve	CHECK	0	N/A	66.86	N/A	N/A	Open
88	Check Valve	CHECK	0	N/A	66.86	N/A	N/A	Open

Reservoir Summary

Jct	Name	Type	Liq. Height (feet)	Liq. Elevation (feet)	Surface Pressure (psia)	Liquid Volume (feet3)	Liquid Mass (lbm)	Net Vol. Flow (gal/min)	Net Mass Flow (lbm/sec)
24	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,717	-238.3
30	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,717	-238.3
36	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,717	-238.3
42	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,717	-238.3
47	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
54	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,717	-238.3
61	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
66	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
71	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
76	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
81	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
86	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
96	Reservoir	Infinite	N/A	20.00	14.70	N/A	N/A	-6,174	-856.9

Pipe Output Table

Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
4	Pipe	6,174	4.3786	44.8662936
X5	Pipe	0	0.0000	0.0000000
6	Pipe	6,174	4.3786	20.6001902
29	Pipe	1,717	6.4599	0.0010284
30	Pipe	1,717	6.4599	0.8316896
31	Pipe	1,717	6.4599	0.0514217
32	Pipe	1,717	6.4599	0.1542651
33	Well 1 to Well 2 - 12" HDPE DR13.5	1,717	6.0719	21.8167310
34	Pipe	1,717	6.4599	0.0010285
35	Pipe	1,717	6.4599	0.8316896
36	Pipe	1,717	6.4599	0.0514217
37	Pipe	1,717	6.4599	0.1542651
38	Pipe	1,717	6.0719	0.6062272
39	Well 2 to Well 3 - 20" HDPE DR13.5	3,434	4.9349	9.1220243
40	Pipe	1,717	6.4599	0.0010285
41	Pipe	1,717	6.4599	0.8316896
42	Pipe	1,717	6.4599	0.0514217
43	Pipe	1,717	6.4599	0.1542651
44	Pipe	1,717	6.0719	0.6062273
45	Pipe	1,717	6.4599	0.0010287
46	Pipe	1,717	6.4599	0.8316896
47	Pipe	1,717	6.4599	0.0514217
48	Pipe	1,717	6.4599	0.1542651
49	Pipe	1,717	6.0719	0.6062273
50	Well 3 to Well 4 - 24" HDPE DR13.5	5,151	5.1410	7.9339072
51	Pipe	0	0.0000	0.0000000
52	Pipe	0	0.0000	0.0000000
53	Pipe	0	0.0000	0.0000000
54	Pipe	0	0.0000	0.0000000
55	Pipe	0	0.0000	0.0000000
56	Well 4 to Well 5/6 Blend - 30" HDPE DR13.5	6,868	4.3869	2.2833119
57	Pipe	1,717	6.4599	0.0010287
58	Pipe	1,717	6.4599	0.8316896
59	Pipe	1,717	6.4599	0.0514217
60	Pipe	1,717	6.4599	0.1542651
61	Pipe	1,717	6.0719	0.6062235
62	Well 6 to Well 5 - 12" HDPE DR13.5	1,717	6.0719	14.2647646

Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
63	Well 11 to Well 9 Blend - 20" HDPE DR13.5	1,717	1.9719	0.2507781
64	North Wells to Desalter - 36" HDPE DR13.5	8,585	3.8080	1.4755265
65	Pipe	0	0.0000	0.0000000
66	Pipe	0	0.0000	0.0000000
67	Pipe	0	0.0000	0.0000000
68	Pipe	0	0.0000	0.0000000
70	Pipe	0	0.0000	0.0000000
71	Pipe	0	0.0000	0.0000000
72	Pipe	0	0.0000	0.0000000
73	Pipe	0	0.0000	0.0000000
75	Pipe	0	0.0000	0.0000000
76	Pipe	0	0.0000	0.0000000
77	Pipe	0	0.0000	0.0000000
78	Pipe	0	0.0000	0.0000000
79	Pipe	0	0.0000	0.0000000
80	Pipe	0	0.0000	0.0000000
81	Pipe	0	0.0000	0.0000000
82	Pipe	0	0.0000	0.0000000
83	Pipe	0	0.0000	0.0000000
84	Pipe	0	0.0000	0.0000000
85	Pipe	0	0.0000	0.0000000
86	Pipe	0	0.0000	0.0000000
87	Pipe	0	0.0000	0.0000000
88	Pipe	0	0.0000	0.0000000
89	Pipe	0	0.0000	0.0000000
90	Pipe	0	0.0000	0.0000000
91	Pipe	0	0.0000	0.0000000
92	Pipe	0	0.0000	0.0000000
93	Pipe	0	0.0000	0.0000000
94	Pipe	0	0.0000	0.0000000
95	Well 7/8 to Well 9 - 20" HDPE DR13.5	0	0.0000	0.0000000
96	Well 9 to Well 10 - 24" HDPE DR13.5	0	0.0000	0.0000000
98	Well 12 to Desalter - 36" HDPE DR13.5	0	0.0000	0.0000000
100	Well 10/11 to Well 12 - 36" HDPE DR13.5	0	0.0000	0.0000000
101	Well 7 to Well 8 Blend - 12" HDPE DR13.5	0	0.0000	0.0000000
102	Well 7 to Well 8 Blend - 12" HDPE DR13.5	0	0.0000	0.0000000
103	Well 10 to Well 11 - 30" HDPE DR13.5	0	0.0000	0.0000000
104	Pipe	6,174	1.9460	0.2057422
105	Pipe	3,087	3.8921	0.3487453
106	Pipe	3,087	4.9259	1.1992354


Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
107	Pipe	0	0.0000	0.0000000
108	Pipe	3,087	0.9730	0.0009715
109	Pipe	3,087	3.8921	0.3487453
110	Pipe	3,087	4.9259	1.1992354
111	Pipe	3,087	0.9730	0.0009715
112	Pipe	0	0.0000	0.0000000
113	Pipe	0	0.0000	0.0000000
114	Pipe	0	0.0000	0.0000000
115	Pipe	6,174	1.9460	0.0035070
116	Pipe	0	0.0000	0.0000000
117	Pipe	0	0.0000	0.0000000
118	Pipe	0	0.0000	0.0000000
119	Pipe	0	0.0000	0.0000000
120	Pipe	6,174	1.9460	0.0035069
121	Pipe	0	0.0000	0.0000000
122	Pipe	6,174	1.9460	0.0035069
123	Pipe	0	0.0000	0.0000000
124	Pipe	0	0.0000	0.0000000

All Junction Table

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
5	PTP Connection	0	0.0	0.0000	0.0000
6	PVCWD Connection	6,174	856.9	0.0000	0.0000
7	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
24	Reservoir	1,717	238.3	0.0000	0.0000
25	Well No. 1	1,717	238.3	0.0000	-216.7528
26	Check Valve	1,717	238.3	0.4568	0.2962
27	Valve	1,717	238.3	0.8328	0.5401
28	Branch	1,717	238.3	0.0000	0.0000
29	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
30	Reservoir	1,717	238.3	0.0000	0.0000
31	Well No. 2	1,717	238.3	0.0000	-195.7628
32	Check Valve	1,717	238.3	0.4568	0.2962
33	Valve	1,717	238.3	0.8328	0.5401
34	Branch	1,717	238.3	0.0000	0.0000
35	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
36	Reservoir	1,717	238.3	0.0000	0.0000
37	Well No. 3	1,717	238.3	0.0000	-186.6736
38	Check Valve	1,717	238.3	0.4568	0.2962
39	Valve	1,717	238.3	0.8328	0.5401
40	Branch	1,717	238.3	0.0000	0.0000
41	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
42	Reservoir	1,717	238.3	0.0000	0.0000
43	Well No. 4	1,717	238.3	0.0000	-178.5595
44	Check Valve	1,717	238.3	0.4568	0.2962
45	Valve	1,717	238.3	0.8328	0.5401
46	Branch	1,717	238.3	0.0000	0.0000
47	Reservoir	0	0.0	0.0000	0.0000
X48	Well No. 5	0	0.0	0.0000	N/A
49	Check Valve	0	0.0	0.0000	0.0000
50	Valve	0	0.0	0.0000	0.0000
51	Branch	0	0.0	0.0000	0.0000
52	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
53	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
54	Reservoir	1,717	238.3	0.0000	0.0000
55	Well No. 6	1,717	238.3	0.0000	-190.3046
56	Check Valve	1,717	238.3	0.4568	0.2962
57	Valve	1,717	238.3	0.8328	0.5401

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
58	Branch	1,717	238.3	0.0000	0.0000
59	Bend	1,717	238.3	0.1908	0.1093
60	Pressure Entering Desalter	N/A	N/A	0.0000	0.0000
61	Reservoir	0	0.0	0.0000	0.0000
X62	Well No. 7	0	0.0	0.0000	N/A
63	Check Valve	0	0.0	0.0000	0.0000
64	Valve	0	0.0	0.0000	0.0000
65	Branch	0	0.0	0.0000	0.0000
66	Reservoir	0	0.0	0.0000	0.0000
X67	Well No. 8	0	0.0	0.0000	N/A
68	Check Valve	0	0.0	0.0000	0.0000
69	Valve	0	0.0	0.0000	0.0000
70	Branch	0	0.0	0.0000	0.0000
71	Reservoir	0	0.0	0.0000	0.0000
X72	Well No. 9	0	0.0	0.0000	N/A
73	Check Valve	0	0.0	0.0000	0.0000
74	Valve	0	0.0	0.0000	0.0000
75	Branch	0	0.0	0.0000	0.0000
76	Reservoir	0	0.0	0.0000	0.0000
X77	Well No. 10	0	0.0	0.0000	N/A
78	Check Valve	0	0.0	0.0000	0.0000
79	Valve	0	0.0	0.0000	0.0000
80	Branch	0	0.0	0.0000	0.0000
81	Reservoir	0	0.0	0.0000	0.0000
X82	Well No. 11	0	0.0	0.0000	N/A
83	Check Valve	0	0.0	0.0000	0.0000
84	Valve	0	0.0	0.0000	0.0000
85	Branch	0	0.0	0.0000	0.0000
86	Reservoir	0	0.0	0.0000	0.0000
X87	Well No. 12	0	0.0	0.0000	N/A
88	Check Valve	0	0.0	0.0000	0.0000
89	Valve	0	0.0	0.0000	0.0000
90	Branch	0	0.0	0.0000	0.0000
91	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
92	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
93	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
94	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
95	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
96	Reservoir	6,174	856.9	0.0000	0.0000
97	Pump	3,087	428.5	0.0000	-154.5463

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
98	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
99	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
100	Pump	3,087	428.5	0.0000	-154.9698
101	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
102	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
X103	Pump	0	0.0	0.0000	N/A
104	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
105	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
106	Dead End	0	0.0	0.0000	0.0000
X107	Pump	0	0.0	0.0000	N/A
108	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
109	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
X110	Pump	0	0.0	0.0000	N/A
111	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
112	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
113	Dead End	0	0.0	0.0000	0.0000



General

Title: AFT Fathom Model
Analysis run on: 5/30/2014 4:40:15 PM
Application version: AFT Fathom Version 8 (2013.10.24)
Input File: C:\Users\byallaly\Desktop\UWCD Raw and Product Water Pumping.fth
Scenario: Base Scenario/20,000 AFY_Worst Water
Output File: C:\Users\byallaly\Desktop\UWCD Raw and Product Water Pumping_4.out

Execution Time= 0.13 seconds
Total Number Of Head/Pressure Iterations= 51
Total Number Of Flow Iterations= 5
Total Number Of Temperature Iterations= 0
Number Of Pipes= 95
Number Of Junctions= 93
Matrix Method= Gaussian Elimination

Pressure/Head Tolerance= 0.0001 relative change
Flow Rate Tolerance= 0.0001 relative change
Temperature Tolerance= 0.0001 relative change
Flow Relaxation= (Automatic)
Pressure Relaxation= (Automatic)

Constant Fluid Property Model
Fluid Database: AFT Standard
Fluid: Water at 1 atm
Max Fluid Temperature Data= 212 deg. F
Min Fluid Temperature Data= 32 deg. F
Temperature= 22 deg. C
Density= 62.29622 lbm/ft³
Viscosity= 2.30822 lbm/hr-ft
Vapor Pressure= 0.38264 psia
Viscosity Model= Newtonian
Apply laminar and non-Newtonian correction to: Pipe Fittings & Losses, Junction K factors, Junction Special Losses, Junction Polynomials
Corrections applied to the following junctions: Branch, Reservoir, Assigned Flow, Assigned Pressure, Area Change, Bend, Tee or Wye, Control Valve, Spray Discharge, Relief Valve

Ambient Pressure (constant)= 1 atm
Gravitational Acceleration= 1 g
Turbulent Flow Above Reynolds Number= 4000
Laminar Flow Below Reynolds Number= 2300
Total Inflow= 29,511 gal/min
Total Outflow= 29,511 gal/min
Maximum Static Pressure is 91.85 psia at Pipe 33 Inlet
Minimum Static Pressure is 14.59 psia at Pipe 104 Inlet
Fixed Energy Cost = 0.0125 U.S. Dollars per kW-hr
The following cost databases were used:
Total of All Model Costs = 0 U.S. Dollars

Warnings

No Warnings

Pump Summary

Jct	Name	Vol. Flow (gal/min)	dH (feet)	Overall Efficiency (Percent)	Speed (Percent)	Overall Power (hp)	NPSHA (feet)	NPSHR (feet)	Energy Cost (U.S. Dollars)
25	Well No. 1	1,907	226.4	100.0	N/A	108.92	39.08	N/A	0
31	Well No. 2	1,907	200.9	100.0	N/A	96.69	40.08	N/A	0
37	Well No. 3	1,907	189.9	100.0	N/A	91.39	40.08	N/A	0
43	Well No. 4	1,907	180.1	100.0	N/A	86.66	42.08	N/A	0
X48	Well No. 5	0	N/A	N/A	0	N/A	N/A	N/A	0
55	Well No. 6	1,907	194.3	100.0	N/A	93.49	42.08	N/A	0
62	Well No. 7	1,907	209.9	100.0	N/A	101.00	42.08	N/A	0
67	Well No. 8	1,907	211.7	100.0	N/A	101.85	45.08	N/A	0
72	Well No. 9	1,907	190.6	100.0	N/A	91.70	44.08	N/A	0
77	Well No. 10	1,907	179.0	100.0	N/A	86.14	48.08	N/A	0
X82	Well No. 11	0	N/A	N/A	0	N/A	N/A	N/A	0
X87	Well No. 12	0	N/A	N/A	0	N/A	N/A	N/A	0
97	Pump	3,087	117.9	100.0	N/A	91.82	39.27	N/A	0
100	Pump	3,087	118.4	100.0	N/A	92.20	39.24	N/A	0
103	Pump	3,087	117.8	100.0	N/A	91.73	39.53	N/A	0
107	Pump	3,087	118.5	100.0	N/A	92.28	39.22	N/A	0
X110	Pump	0	N/A	N/A	0	N/A	N/A	N/A	0

Valve Summary

Jct	Name	Valve Type	Vol. Flow (gal/min)	dH (feet)	P Static In (psia)	Cv	K	Valve State
27	Valve	REGULAR	1,907	0.6662	86.99	3,550	0.8328	Open
33	Valve	REGULAR	1,907	0.6662	76.43	3,550	0.8328	Open
39	Valve	REGULAR	1,907	0.6662	71.66	3,550	0.8328	Open
45	Valve	REGULAR	1,907	0.6662	67.41	3,550	0.8328	Open
50	Valve	REGULAR	0	N/A	66.98	N/A	N/A	Open
57	Valve	REGULAR	1,907	0.6662	74.42	3,550	0.8328	Open
64	Valve	REGULAR	1,907	0.6662	81.16	3,550	0.8328	Open
69	Valve	REGULAR	1,907	0.6662	83.23	3,550	0.8328	Open
74	Valve	REGULAR	1,907	0.6662	73.67	3,550	0.8328	Open
79	Valve	REGULAR	1,907	0.6662	70.40	3,550	0.8328	Open
84	Valve	REGULAR	0	N/A	68.43	N/A	N/A	Open
89	Valve	REGULAR	0	N/A	67.43	N/A	N/A	Open
26	Check Valve	CHECK	1,907	0.3738	87.18	4,739	0.4672	Open
32	Check Valve	CHECK	1,907	0.3738	76.61	4,739	0.4672	Open
38	Check Valve	CHECK	1,907	0.3738	71.85	4,739	0.4672	Open
44	Check Valve	CHECK	1,907	0.3738	67.59	4,739	0.4672	Open
49	Check Valve	CHECK	0	N/A	66.98	N/A	N/A	Open
56	Check Valve	CHECK	1,907	0.3738	74.61	4,739	0.4672	Open
63	Check Valve	CHECK	1,907	0.3738	81.35	4,739	0.4672	Open
68	Check Valve	CHECK	1,907	0.3738	83.42	4,739	0.4672	Open
73	Check Valve	CHECK	1,907	0.3738	73.86	4,739	0.4672	Open
78	Check Valve	CHECK	1,907	0.3738	70.59	4,739	0.4672	Open
83	Check Valve	CHECK	0	N/A	68.43	N/A	N/A	Open
88	Check Valve	CHECK	0	N/A	67.43	N/A	N/A	Open

Reservoir Summary

Jct	Name	Type	Liq. Height (feet)	Liq. Elevation (feet)	Surface Pressure (psia)	Liquid Volume (feet3)	Liquid Mass (lbm)	Net Vol. Flow (gal/min)	Net Mass Flow (lbm/sec)
24	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
30	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
36	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
42	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
47	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
54	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
61	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
66	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
71	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
76	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	-1,907	-264.7
81	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
86	Reservoir	Infinite	N/A	-40.00	14.70	N/A	N/A	0	0.0
96	Reservoir	Infinite	N/A	20.00	14.70	N/A	N/A	-12,348	-1,713.9

Pipe Output Table

Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
4	Pipe	12,348	3.8921	22.7969367
5	Pipe	3,926	1.2375	0.8097693
6	Pipe	8,422	2.6546	5.1676385
29	Pipe	1,907	7.1747	0.0012509
30	Pipe	1,907	7.1747	1.0153057
31	Pipe	1,907	7.1747	0.0625456
32	Pipe	1,907	7.1747	0.1876368
33	Well 1 to Well 2 - 12" HDPE DR13.5	1,907	6.7438	26.4246952
34	Pipe	1,907	7.1747	0.0012510
35	Pipe	1,907	7.1747	1.0153057
36	Pipe	1,907	7.1747	0.0625456
37	Pipe	1,907	7.1747	0.1876368
38	Pipe	1,907	6.7438	0.7384383
39	Well 2 to Well 3 - 20" HDPE DR13.5	3,814	5.4809	11.0514290
40	Pipe	1,907	7.1747	0.0012510
41	Pipe	1,907	7.1747	1.0153057
42	Pipe	1,907	7.1747	0.0625456
43	Pipe	1,907	7.1747	0.1876368
44	Pipe	1,907	6.7438	0.7384384
45	Pipe	1,907	7.1747	0.0012511
46	Pipe	1,907	7.1747	1.0153057
47	Pipe	1,907	7.1747	0.0625456
48	Pipe	1,907	7.1747	0.1876368
49	Pipe	1,907	6.7438	0.7384383
50	Well 3 to Well 4 - 24" HDPE DR13.5	5,721	5.7099	9.6151748
51	Pipe	0	0.0000	0.0000000
52	Pipe	0	0.0000	0.0000000
53	Pipe	0	0.0000	0.0000000
54	Pipe	0	0.0000	0.0000000
55	Pipe	0	0.0000	0.0000000
56	Well 4 to Well 5/6 Blend - 30" HDPE DR13.5	7,628	4.8723	2.7672518
57	Pipe	1,907	7.1747	0.0012511
58	Pipe	1,907	7.1747	1.0153057
59	Pipe	1,907	7.1747	0.0625456
60	Pipe	1,907	7.1747	0.1876368
61	Pipe	1,907	6.7438	0.7384382
62	Well 6 to Well 5 - 12" HDPE DR13.5	1,907	6.7438	17.2776857

Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
63	Well 11 to Well 9 Blend - 20" HDPE DR13.5	1,907	2.1901	0.3033314
64	North Wells to Desalter - 36" HDPE DR13.5	9,535	4.2294	1.7882675
65	Pipe	1,907	7.1747	0.0012511
66	Pipe	1,907	7.1747	1.0153057
67	Pipe	1,907	7.1747	0.0625456
68	Pipe	1,907	7.1747	0.1876368
70	Pipe	1,907	7.1747	0.0012509
71	Pipe	1,907	7.1747	1.0153057
72	Pipe	1,907	7.1747	0.0625456
73	Pipe	1,907	7.1747	0.1876368
75	Pipe	1,907	7.1747	0.0012513
76	Pipe	1,907	7.1747	1.0153057
77	Pipe	1,907	7.1747	0.0625456
78	Pipe	1,907	7.1747	0.1876368
79	Pipe	1,907	6.7438	0.7384383
80	Pipe	1,907	7.1747	0.0012506
81	Pipe	1,907	7.1747	1.0153057
82	Pipe	1,907	7.1747	0.0625456
83	Pipe	1,907	7.1747	0.1876368
84	Pipe	1,907	6.7438	0.7384382
85	Pipe	0	0.0000	0.0000000
86	Pipe	0	0.0000	0.0000000
87	Pipe	0	0.0000	0.0000000
88	Pipe	0	0.0000	0.0000000
89	Pipe	0	0.0000	0.0000000
90	Pipe	0	0.0000	0.0000000
91	Pipe	0	0.0000	0.0000000
92	Pipe	0	0.0000	0.0000000
93	Pipe	0	0.0000	0.0000000
94	Pipe	0	0.0000	0.0000000
95	Well 7/8 to Well 9 - 20" HDPE DR13.5	3,814	5.4816	6.7269729
96	Well 9 to Well 10 - 24" HDPE DR13.5	5,721	5.7099	11.3314816
98	Well 12 to Desalter - 36" HDPE DR13.5	7,628	3.3835	1.3247180
100	Well 10/11 to Well 12 - 36" HDPE DR13.5	7,628	3.3835	2.3098418
101	Well 7 to Well 8 Blend - 12" HDPE DR13.5	1,907	6.7438	15.3665173
102	Well 7 to Well 8 Blend - 12" HDPE DR13.5	1,907	6.7438	13.5879313
103	Well 10 to Well 11 - 30" HDPE DR13.5	7,628	4.8723	0.1024908
104	Pipe	12,348	3.8921	0.8092790
105	Pipe	3,087	3.8921	0.3487453
106	Pipe	3,087	4.9259	1.1992354

Pipe	Name	Vol. Flow Rate (gal/min)	Velocity (feet/sec)	dH (feet)
107	Pipe	0	0.0000	0.0000000
108	Pipe	9,261	2.9191	0.0074305
109	Pipe	3,087	3.8921	0.3487453
110	Pipe	3,087	4.9259	1.1992354
111	Pipe	3,087	0.9730	0.0009715
112	Pipe	6,174	1.9460	0.0035069
113	Pipe	3,087	3.8921	0.3487453
114	Pipe	3,087	4.9259	1.1992354
115	Pipe	6,174	1.9460	0.0035069
116	Pipe	0	0.0000	0.0000000
117	Pipe	3,087	0.9730	0.0009715
118	Pipe	3,087	3.8921	0.3487453
119	Pipe	3,087	4.9259	1.1992354
120	Pipe	9,261	2.9191	0.0074305
121	Pipe	0	0.0000	0.0000000
122	Pipe	12,348	3.8921	0.0126588
123	Pipe	0	0.0000	0.0000000
124	Pipe	0	0.0000	0.0000000

All Junction Table

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
5	PTP Connection	3,926	544.9	0.0000	0.0000
6	PVCWD Connection	8,422	1,169.0	0.0000	0.0000
7	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
24	Reservoir	1,907	264.7	0.0000	0.0000
25	Well No. 1	1,907	264.7	0.0000	-226.3566
26	Check Valve	1,907	264.7	0.4672	0.3738
27	Valve	1,907	264.7	0.8328	0.6662
28	Branch	1,907	264.7	0.0000	0.0000
29	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
30	Reservoir	1,907	264.7	0.0000	0.0000
31	Well No. 2	1,907	264.7	0.0000	-200.9423
32	Check Valve	1,907	264.7	0.4672	0.3738
33	Valve	1,907	264.7	0.8328	0.6662
34	Branch	1,907	264.7	0.0000	0.0000
35	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
36	Reservoir	1,907	264.7	0.0000	0.0000
37	Well No. 3	1,907	264.7	0.0000	-189.9314
38	Check Valve	1,907	264.7	0.4672	0.3738
39	Valve	1,907	264.7	0.8328	0.6662
40	Branch	1,907	264.7	0.0000	0.0000
41	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
42	Reservoir	1,907	264.7	0.0000	0.0000
43	Well No. 4	1,907	264.7	0.0000	-180.0939
44	Check Valve	1,907	264.7	0.4672	0.3738
45	Valve	1,907	264.7	0.8328	0.6662
46	Branch	1,907	264.7	0.0000	0.0000
47	Reservoir	0	0.0	0.0000	0.0000
X48	Well No. 5	0	0.0	0.0000	N/A
49	Check Valve	0	0.0	0.0000	0.0000
50	Valve	0	0.0	0.0000	0.0000
51	Branch	0	0.0	0.0000	0.0000
52	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
53	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
54	Reservoir	1,907	264.7	0.0000	0.0000
55	Well No. 6	1,907	264.7	0.0000	-194.3068
56	Check Valve	1,907	264.7	0.4672	0.3738
57	Valve	1,907	264.7	0.8328	0.6662

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
58	Branch	1,907	264.7	0.0000	0.0000
59	Bend	1,907	264.7	0.1908	0.1348
60	Pressure Entering Desalter	N/A	N/A	0.0000	0.0000
61	Reservoir	1,907	264.7	0.0000	0.0000
62	Well No. 7	1,907	264.7	0.0000	-209.8959
63	Check Valve	1,907	264.7	0.4672	0.3738
64	Valve	1,907	264.7	0.8328	0.6662
65	Branch	1,907	264.7	0.0000	0.0000
66	Reservoir	1,907	264.7	0.0000	0.0000
67	Well No. 8	1,907	264.7	0.0000	-211.6745
68	Check Valve	1,907	264.7	0.4672	0.3738
69	Valve	1,907	264.7	0.8328	0.6662
70	Branch	1,907	264.7	0.0000	0.0000
71	Reservoir	1,907	264.7	0.0000	0.0000
72	Well No. 9	1,907	264.7	0.0000	-190.5735
73	Check Valve	1,907	264.7	0.4672	0.3738
74	Valve	1,907	264.7	0.8328	0.6662
75	Branch	1,907	264.7	0.0000	0.0000
76	Reservoir	1,907	264.7	0.0000	0.0000
77	Well No. 10	1,907	264.7	0.0000	-179.0197
78	Check Valve	1,907	264.7	0.4672	0.3738
79	Valve	1,907	264.7	0.8328	0.6662
80	Branch	1,907	264.7	0.0000	0.0000
81	Reservoir	0	0.0	0.0000	0.0000
X82	Well No. 11	0	0.0	0.0000	N/A
83	Check Valve	0	0.0	0.0000	0.0000
84	Valve	0	0.0	0.0000	0.0000
85	Branch	0	0.0	0.0000	0.0000
86	Reservoir	0	0.0	0.0000	0.0000
X87	Well No. 12	0	0.0	0.0000	N/A
88	Check Valve	0	0.0	0.0000	0.0000
89	Valve	0	0.0	0.0000	0.0000
90	Branch	0	0.0	0.0000	0.0000
91	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
92	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
93	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
94	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
95	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
96	Reservoir	12,348	1,713.9	0.0000	0.0000
97	Pump	3,087	428.5	0.0000	-117.8860

Jct	Name	Vol. Flow Rate Thru Jct (gal/min)	Mass Flow Rate Thru Jct (lbm/sec)	Loss Factor (K)	dH (feet)
98	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
99	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
100	Pump	3,087	428.5	0.0000	-118.3712
101	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
102	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
103	Pump	3,087	428.5	0.0000	-117.7742
104	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
105	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
106	Dead End	0	0.0	0.0000	0.0000
107	Pump	3,087	428.5	0.0000	-118.4700
108	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
109	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
X110	Pump	0	0.0	0.0000	N/A
111	Tee or Wye	N/A	N/A	See Mult. Losses	See Mult. Losses
112	Tee or Wye	N/A	N/A	See Mult. Losses	0.0000
113	Dead End	0	0.0	0.0000	0.0000

APPENDIX B – SCALE INHIBITOR PROJECTIONS

Project Details

Project: South Oxnard Plain Desalter
Permeate Flowrate: 6180USGPM This is split into 5 trains of 1236.0USGPM
System Recovery: 80%

Antiscalant

Vitec 4000 is the selected product at a dose of 3.00mg/l. Assuming the plant operates continuously, then this will require 101385lb of antiscalant per year. This may be supplied in 41 x 2500lb Totes, 203 x 500lb Drums, or 2253 x 45lb Pails.

Chemical Cleaning

The chemical cleaning calculation has not been completed for this project.

Biocide

No biocide has been selected for this system. It is always recommended that a biocide injection point be included to allow for the retrofit of a biocide system at a later date.

Coagulant

No coagulant has been selected for this system. It is always recommended that a coagulant injection point be included to allow for the retrofit of a coagulant system at a later date.

Dechlorination

No dechlorination has been selected for this system.

Project Details

Project: South Oxnard Plain Desalter
 Permeate Flowrate: 6180USGPM This is split into 5 trains of 1236.0USGPM
 System Recovery: 80%

Antiscalant Projection

The projection is based on the following feed water analysis. The adjusted feed is the analysis after pH correction, and any ions have been added to balance the analysis. The concentrate analysis has been calculated based on the adjusted feed, using typical rejections of a High Rejection polyamide membrane.

Ion	Feed Water	Adjusted Feed	Concentrate
Sodium	1077.00	1078.66	5342.96 mg/l
Potassium	19.10	19.10	94.35 mg/l
Calcium	810.00	810.00	4044.13 mg/l
Magnesium	303.00	303.00	1512.32 mg/l
Iron	0.00	0.00	0.00 mg/l
Manganese	0.00	0.00	0.00 mg/l
Barium	0.04	0.04	0.20 mg/l
Strontium	4.80	4.80	23.97 mg/l
Aluminium	0.00	0.00	0.00 mg/l
Chloride	3257.00	3257.00	16148.71 mg/l
Sulfate	855.00	901.96	4503.28 mg/l
Bicarbonate	193.00	133.75	657.33 mg/l
Nitrate	1.20	1.20	5.76 mg/l
Fluoride	0.40	0.40	1.98 mg/l
Phosphate	0.00	0.00	0.00 mg/l
Silica	31.70	31.70	157.12 mg/l
CO2	22.21	82.65	82.65 mg/l
TDS		6541.61	32492.11
pH	7.13	6.40	7.09

Water Source: Well Water

Water Temperature: 18.9° C

Product Choice

Vitec Choice: Vitec 4000
 Dosage: 3.00mg/l
 Usage: 277.77 lb per day.

Application

Dosed Solution Strength: 100%
 Pump Rate: 28.98USGPD
 76.24ml/m

There is one dosing pump and chemical tank per membrane train.
 With 5 trains, each pump will deliver 5.80USGPD

pH Correction

Chemical choice: Sulfuric acid
 Dosage: 47.45ppm 100% H2SO4

Project Details

Project: South Oxnard Plain Desalter
Permeate Flowrate: 6180USGPM This is split into 5 trains of 1236.0USGPM
System Recovery: 80%

Scaling Potential.

Stiff and Davies Index (S&DI)

The reject stream has a S&DI of 0.77.
Vitec 4000 has a limit of 3.00

Calcium Carbonate Precipitation Potential (CCPP)

The concentrate has a CCPP of 334mg/l.
This is within the limits of Vitec 4000.

Calcium Sulfate

The concentrate has a calcium sulphate saturation of 319.94%.
This is within the limits of Vitec 4000.

Barium Sulfate

The concentrate has a barium sulphate saturation of 1200.50%.
This is within the limits of Vitec 4000.

Strontium Sulfate

The concentrate has a strontium sulphate saturation of 76.23%.
This is within the limits of Vitec 4000.

Calcium Fluoride

The concentrate has a calcium fluoride saturation of 370.84%.
This is within the limits of Vitec 4000.

Silica


The concentrate has a silica level of 157.12mg/l.
This is within the limits of Vitec 4000.

Magnesium Hydroxide

The concentrate has a magnesium hydroxide saturation of 0.00%.

Calcium Phosphate

No phosphate was included in the feed water analysis.




While every effort has been made to ensure the accuracy of this program, no warranty, expressed or implied, is given as actual application of the products is outside the control of Avista Technologies.

Project Details

Project: South Oxnard Plain Desalter
 Permeate Flowrate: 6180USGPM This is split into 5 trains of 1236.0USGPM
 System Recovery: 80%

Saturation Indices



Product Choice

Vitec Choice: Vitec 4000
 Dosage: 3.00mg/l
 Usage: 277.77 lb per day.

Application

Dosed Solution Strength: 100%
 Pump Rate: 28.98USGPD
 76.24ml/m

There is one dosing pump and chemical tank per membrane train.
 With 5 trains, each pump will deliver 5.80USGPD

pH Correction

Chemical choice: Sulfuric acid
 Dosage: 47.45ppm 100% H2SO4

Project Details

Project: South Oxnard Plain Desalter
Permeate Flowrate: 6180USGPM This is split into 5 trains of 1236.0USGPM
System Recovery: 72%

Antiscalant

Vitec 4000 is the selected product at a dose of 5.20mg/l. Assuming the plant operates continuously, then this will require 195104lb of antiscalant per year. This may be supplied in 79 x 2500lb Totes, 391 x 500lb Drums, or 4336 x 45lb Pails.

Chemical Cleaning

The chemical cleaning calculation has not been completed for this project.

Biocide

No biocide has been selected for this system. It is always recommended that a biocide injection point be included to allow for the retrofit of a biocide system at a later date.

Coagulant

No coagulant has been selected for this system. It is always recommended that a coagulant injection point be included to allow for the retrofit of a coagulant system at a later date.

Dechlorination

No dechlorination has been selected for this system.

Project Details

Project: South Oxnard Plain Desalter
 Permeate Flowrate: 6180USGPM This is split into 5 trains of 1236.0USGPM
 System Recovery: 72%

Antiscalant Projection

The projection is based on the following feed water analysis. The adjusted feed is the analysis after pH correction, and any ions have been added to balance the analysis. The concentrate analysis has been calculated based on the adjusted feed, using typical rejections of a High Rejection polyamide membrane.

Ion	Feed Water	Adjusted Feed	Concentrate
Sodium	1615.00	1645.96	5835.01 mg/l
Potassium	28.60	28.60	101.17 mg/l
Calcium	1216.00	1216.00	4337.88 mg/l
Magnesium	454.00	454.00	1619.16 mg/l
Iron	0.00	0.00	0.00 mg/l
Manganese	0.00	0.00	0.00 mg/l
Barium	0.06	0.06	0.21 mg/l
Strontium	7.20	7.20	25.68 mg/l
Aluminium	0.00	0.00	0.00 mg/l
Chloride	4885.00	4885.00	17330.94 mg/l
Sulfate	1278.00	1349.65	4814.65 mg/l
Bicarbonate	369.00	278.71	981.97 mg/l
Nitrate	2.00	2.00	6.92 mg/l
Fluoride	0.60	0.60	2.13 mg/l
Phosphate	0.00	0.00	0.00 mg/l
Silica	47.50	47.50	168.48 mg/l
CO2	41.48	133.69	133.69 mg/l
TDS		9915.28	35224.20
pH	7.13	6.50	7.06

Water Source: Well Water

Water Temperature: 18.9° C

Product Choice

Vitec Choice: Vitec 4000
 Dosage: 5.20mg/l
 Usage: 534.53 lb per day.

Application

Dosed Solution Strength: 100%
 Pump Rate: 55.78USGPD
 146.72ml/m

There is one dosing pump and chemical tank per membrane train.
 With 5 trains, each pump will deliver 11.16USGPD

pH Correction

Chemical choice: Sulfuric acid
 Dosage: 72.39ppm 100% H2SO4

Project Details

Project: South Oxnard Plain Desalter
Permeate Flowrate: 6180USGPM This is split into 5 trains of 1236.0USGPM
System Recovery: 72%

Scaling Potential.

Stiff and Davies Index (S&DI)

The reject stream has a S&DI of 0.91.
Vitec 4000 has a limit of 3.00

Calcium Carbonate Precipitation Potential (CCPP)

The concentrate has a CCPP of 556mg/l.
This is within the limits of Vitec 4000.

Calcium Sulfate

The concentrate has a calcium sulphate saturation of 344.91%.
This is within the limits of Vitec 4000.

Barium Sulfate

The concentrate has a barium sulphate saturation of 1286.43%.
This is within the limits of Vitec 4000.

Strontium Sulfate

The concentrate has a strontium sulphate saturation of 81.43%.
This is within the limits of Vitec 4000.

Calcium Fluoride

The concentrate has a calcium fluoride saturation of 443.81%.
This is within the limits of Vitec 4000.

Silica


The concentrate has a silica level of 168.48mg/l.
This is within the limits of Vitec 4000.

Magnesium Hydroxide

The concentrate has a magnesium hydroxide saturation of 0.00%.

Calcium Phosphate

No phosphate was included in the feed water analysis.




While every effort has been made to ensure the accuracy of this program, no warranty, expressed or implied, is given as actual application of the products is outside the control of Avista Technologies.

Project Details

Project: South Oxnard Plain Desalter
 Permeate Flowrate: 6180USGPM This is split into 5 trains of 1236.0USGPM
 System Recovery: 72%

Saturation Indices



Product Choice

Vitec Choice: Vitec 4000
 Dosage: 5.20mg/l
 Usage: 534.53 lb per day.

Application

Dosed Solution Strength: 100%
 Pump Rate: 55.78USGPD
 146.72ml/m

There is one dosing pump and chemical tank per membrane train.
 With 5 trains, each pump will deliver 11.16USGPD

pH Correction

Chemical choice: Sulfuric acid
 Dosage: 72.39ppm 100% H2SO4

**APPENDIX C – REVERSE OSMOSIS
PERFORMANCE PROJECTIONS**

Reverse Osmosis System Analysis for FILMTEC™ Membranes
 Project: UWCD South Oxnard Desal Feasibility Study
 Brandon C. Yallaly, Carollo Engineers, Inc.

ROSA 9.1 ConfigDB u399339_282
 Case: 2
 5/6/2014

Project Information:

Case-specific: Design Water Quality

System Details

Feed Flow to Stage 1	1545.04 gpm	Pass 1 Permeate Flow	1236.08 gpm	Osmotic Pressure:	
Raw Water Flow to System	1545.04 gpm	Pass 1 Recovery	80.00 %	Feed	55.98 psig
Feed Pressure	263.30 psig	Feed Temperature	18.9 C	Concentrate	268.00 psig
Flow Factor	0.85	Feed TDS	6556.75 mg/l	Average	161.99 psig
Chem. Dose (100% H2SO4)	43.87 mg/l	Number of Elements	336	Average NDP	190.52 psig
Total Active Area	134400.00 ft²	Average Pass 1 Flux	13.24 gfd	Power	299.60 kW
Water Classification: Well Water SDI < 3				Specific Energy	4.04 kWh/kgal

Stage	Element	#PV	#Ele	Feed Flow (gpm)	Feed Press (psig)	Recirc Flow (gpm)	Conc Flow (gpm)	Conc Press (psig)	Perm Flow (gpm)	Avg Flux (gfd)	Perm Press (psig)	Boost Press (psig)	Perm TDS (mg/l)
1	BW30XFR-400/34i	32	7	1545.04	258.30	0.00	720.44	246.47	824.60	13.25	20.00	0.00	48.39
2	SW30ULE-400i	16	7	720.44	441.47	0.00	308.96	418.12	411.48	13.23	20.00	200.00	55.71

Name	Feed	Adjusted Feed	Concentrate		Permeate		
			Stage 1	Stage 2	Stage 1	Stage 2	Total
NH4+ + NH3	1.89	1.90	4.02	9.28	0.06	0.08	0.07
K	19.10	19.10	40.64	94.29	0.28	0.36	0.31
Na	1077.00	1077.00	2297.60	5337.74	10.58	14.93	12.03
Mg	303.00	303.00	648.01	1509.50	1.57	1.17	1.43
Ca	810.00	810.00	1732.43	4035.68	4.08	3.06	3.74
Sr	4.80	4.80	10.27	23.92	0.02	0.02	0.02
Ba	0.04	0.04	0.08	0.19	0.00	0.00	0.00
CO3	0.80	0.14	0.99	8.97	0.00	0.00	0.00
HCO3	246.00	192.72	408.45	934.97	3.55	3.49	3.53
NO3	1.20	1.20	2.48	5.56	0.08	0.16	0.11
Cl	3257.38	3257.40	6957.26	16183.66	24.88	29.67	26.48
F	0.40	0.40	0.85	1.97	0.01	0.01	0.01
SO4	812.00	854.97	1830.75	4267.51	2.44	1.13	2.01
SiO2	31.70	31.70	67.90	157.39	0.07	0.72	0.28
Boron	0.42	0.41	0.74	1.50	0.13	0.16	0.14
CO2	16.07	54.93	55.35	59.11	54.63	55.79	55.01
TDS	6567.69	6556.75	14005.96	32579.22	48.39	55.71	50.83
pH	7.14	6.50	6.73	6.95	5.03	5.02	5.03

*Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. **DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, IS GIVEN.** Neither FilmTec Corporation nor The Dow Chemical Company assume any obligation or liability for results obtained or damages incurred from the application of this information. Because use conditions and applicable laws may differ from one location to another and may change with time, customer is responsible for determining whether products are appropriate for customer's use. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Reverse Osmosis System Analysis for FILMTEC™ Membranes
 Project: UWCD South Oxnard Desal Feasibility Study
 Brandon C. Yallaly, Carollo Engineers, Inc.

ROSA 9.1 ConfigDB u399339_282
 Case: 2
 5/6/2014

Design Warnings

-None-

Solubility Warnings

Langelier Saturation Index > 0

Stiff & Davis Stability Index > 0

CaSO₄ (% Saturation) > 100%

BaSO₄ (% Saturation) > 100%

CaF₂ (% Saturation) > 100%

SiO₂ (% Saturation) > 100%

Antiscalants may be required. Consult your antiscalant manufacturer for dosing and maximum allowable system recovery.

Stage Details

Stage 1 Element Recovery		Perm Flow (gpm)	Perm TDS (mg/l)	Feed Flow (gpm)	Feed TDS (mg/l)	Feed Press (psig)
1	0.09	4.54	25.70	48.28	6556.75	258.30
2	0.10	4.29	30.57	43.74	7235.04	255.82
3	0.10	4.01	36.96	39.45	8017.87	253.65
4	0.11	3.72	45.50	35.44	8921.93	251.76
5	0.11	3.41	57.16	31.72	9963.56	250.13
6	0.11	3.07	73.38	28.31	11156.18	248.72
7	0.11	2.72	96.35	25.24	12505.96	247.51
Stage 2 Element Recovery		Perm Flow (gpm)	Perm TDS (mg/l)	Feed Flow (gpm)	Feed TDS (mg/l)	Feed Press (psig)
1	0.11	5.14	28.27	45.03	14005.96	441.47
2	0.12	4.70	34.49	39.88	15808.82	436.17
3	0.12	4.23	42.90	35.18	17917.93	431.70
4	0.12	3.71	54.51	30.95	20358.20	427.97
5	0.12	3.18	70.80	27.24	23125.32	424.85
6	0.11	2.64	94.02	24.06	26168.21	422.23
7	0.10	2.12	127.49	21.43	29374.65	420.02

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume any obligation or liability for results obtained or damages incurred from the application of this information. Because use conditions and applicable laws may differ from one location to another and may change with time, customer is responsible for determining whether products are appropriate for customer's use. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Scaling Calculations

	Raw Water	Adjusted Feed	Concentrate
pH	7.14	6.50	6.95
Langelier Saturation Index	0.64	-0.11	1.69
Stiff & Davis Stability Index	0.26	-0.49	0.69
Ionic Strength (Molal)	0.16	0.16	0.79
TDS (mg/l)	6567.69	6556.75	32579.22
HCO ₃	246.00	192.72	934.97
CO ₂	16.07	54.92	59.09
CO ₃	0.80	0.14	8.97
CaSO ₄ (% Saturation)	41.53	43.63	284.05
BaSO ₄ (% Saturation)	163.06	171.21	945.20
SrSO ₄ (% Saturation)	10.21	10.73	66.45
CaF ₂ (% Saturation)	17.23	17.23	2088.41
SiO ₂ (% Saturation)	28.10	26.45	138.52
Mg(OH) ₂ (% Saturation)	0.00	0.00	0.00

To balance: 0.00 mg/l Na added to feed.

Reverse Osmosis System Analysis for FILMTEC™ Membranes
 Project: UWCD South Oxnard Desal Feasibility Study
 Brandon C. Yallaly, Carollo Engineers, Inc.

ROSA 9.1 ConfigDB u399339_282
 Case: 1
 4/24/2014

Project Information:

Case-specific: Worst Case Water Quality

System Details

Feed Flow to Stage 1	1716.39 gpm	Pass 1 Permeate Flow	1235.56 gpm	Osmotic Pressure:	
Raw Water Flow to System	1716.39 gpm	Pass 1 Recovery	71.99 %	Feed	82.71 psig
Feed Pressure	308.80 psig	Feed Temperature	18.9 C	Concentrate	287.47 psig
Flow Factor	0.85	Feed TDS	9836.29 mg/l	Average	185.09 psig
Chem. Dose (100% H2SO4)	61.25 mg/l	Number of Elements	336	Average NDP	200.47 psig
Total Active Area	134400.00 ft²	Average Pass 1 Flux	13.24 gfd	Power	384.87 kW
Water Classification: Well Water SDI < 3				Specific Energy	5.19 kWh/kgal

Stage	Element	#PV	#Ele	Feed Flow (gpm)	Feed Press (psig)	Recirc Flow (gpm)	Conc Flow (gpm)	Conc Press (psig)	Perm Flow (gpm)	Avg Flux (gfd)	Perm Press (psig)	Boost Press (psig)	Perm TDS (mg/l)
1	BW30XFR-400/34i	32	7	1716.39	303.80	0.00	888.32	289.53	828.07	13.31	20.00	0.00	79.69
2	SW30ULE-400i	16	7	888.32	484.53	0.00	480.82	448.63	407.50	13.10	20.00	200.00	65.65

Name	Feed	Adjusted Feed	Concentrate		Permeate		
			Stage 1	Stage 2	Stage 1	Stage 2	Total
NH4+ + NH3	2.89	2.90	5.53	10.14	0.11	0.09	0.10
K	28.60	28.60	54.82	100.92	0.47	0.43	0.46
Na	1615.00	1615.02	3104.12	5719.93	17.57	17.59	17.58
Mg	454.00	454.00	874.79	1615.02	2.59	1.36	2.18
Ca	1216.00	1216.00	2343.21	4326.03	6.77	3.59	5.72
Sr	7.20	7.20	13.87	25.61	0.04	0.02	0.03
Ba	0.06	0.06	0.11	0.21	0.00	0.00	0.00
CO3	1.64	0.30	1.71	8.35	0.00	0.00	0.00
HCO3	369.00	295.47	563.84	1028.15	5.56	4.15	5.09
NO3	2.00	2.00	3.72	6.70	0.15	0.22	0.17
Cl	4885.05	4885.08	9400.38	17337.55	41.25	34.90	39.15
F	0.60	0.60	1.15	2.12	0.01	0.01	0.01
SO4	1218.00	1278.00	2465.59	4554.05	4.01	1.31	3.12
SiO2	47.50	47.50	91.69	168.68	0.10	0.84	0.34
Boron	0.62	0.62	1.03	1.72	0.19	0.20	0.19
CO2	21.64	75.59	76.28	79.36	75.40	76.69	75.82
TDS	9851.10	9836.29	18930.40	34913.28	79.69	65.65	75.05
pH	7.14	6.50	6.69	6.86	5.08	4.95	5.04

*Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. **DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, IS GIVEN.** Neither FilmTec Corporation nor The Dow Chemical Company assume any obligation or liability for results obtained or damages incurred from the application of this information. Because use conditions and applicable laws may differ from one location to another and may change with time, customer is responsible for determining whether products are appropriate for customer's use. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Reverse Osmosis System Analysis for FILMTEC™ Membranes
 Project: UWCD South Oxnard Desal Feasibility Study
 Brandon C. Yallaly, Carollo Engineers, Inc.

ROSA 9.1 ConfigDB u399339_282

Case: 1

4/24/2014

Design Warnings

-None-

Solubility Warnings

Langelier Saturation Index > 0

Stiff & Davis Stability Index > 0

CaSO4 (% Saturation) > 100%

BaSO4 (% Saturation) > 100%

CaF2 (% Saturation) > 100%

SiO2 (% Saturation) > 100%

Antiscalants may be required. Consult your antiscalant manufacturer for dosing and maximum allowable system recovery.

Stage Details

Stage 1 Element Recovery		Perm Flow (gpm)	Perm TDS (mg/l)	Feed Flow (gpm)	Feed TDS (mg/l)	Feed Press (psig)
1	0.09	4.70	41.59	53.64	9836.29	303.80
2	0.09	4.39	50.10	48.94	10776.70	300.92
3	0.09	4.06	61.26	44.55	11832.71	298.38
4	0.09	3.72	76.07	40.49	13012.56	296.14
5	0.09	3.37	96.01	36.78	14320.40	294.16
6	0.09	3.01	123.12	33.41	15752.95	292.42
7	0.09	2.65	160.24	30.41	17297.51	290.89
Stage 2 Element Recovery		Perm Flow (gpm)	Perm TDS (mg/l)	Feed Flow (gpm)	Feed TDS (mg/l)	Feed Press (psig)
1	0.09	5.01	37.66	55.52	18930.40	484.53
2	0.09	4.56	44.81	50.51	20802.30	477.23
3	0.09	4.10	53.92	45.96	22861.05	470.84
4	0.09	3.63	65.64	41.86	25094.80	465.24
5	0.08	3.17	80.89	38.22	27474.39	460.32
6	0.08	2.72	100.83	35.05	29950.53	455.97
7	0.07	2.28	127.16	32.34	32456.79	452.11

Permeate Flux reported by ROSA is calculated based on ACTIVE membrane area. DISCLAIMER: NO WARRANTY, EXPRESSED OR IMPLIED, AND NO WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, IS GIVEN. Neither FilmTec Corporation nor The Dow Chemical Company assume any obligation or liability for results obtained or damages incurred from the application of this information. Because use conditions and applicable laws may differ from one location to another and may change with time, customer is responsible for determining whether products are appropriate for customer's use. FilmTec Corporation and The Dow Chemical Company assume no liability, if, as a result of customer's use of the ROSA membrane design software, the customer should be sued for alleged infringement of any patent not owned or controlled by the FilmTec Corporation nor The Dow Chemical Company.

Scaling Calculations

	Raw Water	Adjusted Feed	Concentrate
pH	7.14	6.50	6.86
Langelier Saturation Index	0.98	0.25	1.67
Stiff & Davis Stability Index	0.44	-0.29	0.65
Ionic Strength (Molal)	0.23	0.23	0.85
TDS (mg/l)	9851.10	9836.29	34913.28
HCO ₃	369.00	295.47	1028.15
CO ₂	21.64	75.58	79.34
CO ₃	1.64	0.30	8.35
CaSO ₄ (% Saturation)	67.32	70.49	307.34
BaSO ₄ (% Saturation)	248.26	259.84	1028.90
SrSO ₄ (% Saturation)	15.77	16.50	72.43
CaF ₂ (% Saturation)	58.19	58.19	2574.52
SiO ₂ (% Saturation)	42.11	39.63	146.85
Mg(OH) ₂ (% Saturation)	0.00	0.00	0.00

To balance: 0.02 mg/l Na added to feed.

APPENDIX D – DETAILED O&M ESTIMATE

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Design Water

<i>Unit Costs</i>		
	Power (\$/kWh):	\$0.125
	Lime (slaked) (\$/lb):	\$0.20
	Sulfuric Acid (\$/lb):	\$0.03
	Scale Inhibitor (\$/lb):	\$0.95
	Sodium Hypochlorite (\$/lb):	\$0.35
	Membrane Elements - 8 inch diameter(\$/element):	\$500.00
	Cartridge Filters (\$/filter):	\$12.00
	Step 1 Cleaning Chemical Cost (\$/lb):	\$2.82
	Step 2 Cleaning Chemical Cost (\$/lb):	\$3.16
	Step 3 Cleaning Chemical Cost (\$/lb):	\$2.00
	Plant Operating Factor:	0.98
<i>Well 1</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	226
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	156.3
	Power (kW):	116.6
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	1000848
<i>Well 2</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	200
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	138.4
	Power (kW):	103.2
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	885706
<i>Well 3</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	188
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	130.1
	Power (kW):	97.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	832564
<i>Well 4</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	194
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	134.2
	Power (kW):	100.1
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	859135
<i>Well 5</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Design Water

<i>Well 6</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 7</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 8</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 9</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 10</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 11</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 12</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Design Water

<i>RO Feed Pumps</i>		
	Number of Pumps:	5.0
	Flowrate Per Pump (gpm):	1545
	Discharge Head (ft):	538
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	297.9
	Power (kW):	222.1
	Operational Factor:	0.98
	Yearly Power Usage Per Pump - Existing (kWh/yr):	1906855
	Total Yearly Power Usage (kWh/yr):	9534273
<i>Primary RO Stage 2 Boost Pumps</i>		
	Number of Pumps:	5.0
	Flowrate Per Pump (gpm):	720
	Discharge Head (ft):	462
	Pump Efficiency (%):	74.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	120.8
	Power (kW):	90.1
	Operational Factor:	0.98
	Yearly Power Usage Per Pump (kWh/yr):	773061
	Total Yearly Power Usage (kWh/yr):	3865307
<i>Product Water Pumps</i>		
	Total Number of Pumps:	2.0
	Flowrate Per Pump (gpm):	3090
	Discharge Head (ft):	155
	Pump Efficiency (%):	84.0%
	Motor Efficiency (%):	92.5%
	Power (hp):	155.7
	Power (kW):	116.1
	Operational Factor:	0.98
	Total Yearly Power Usage (kWh/yr):	1993010
<i>Chemical Usage</i>		
Lime	Post Treatment (lbs/day):	4320.0
	Operating Factor:	0.98
	Total Lime Usage (lbs/yr):	1545247
Sulfuric Acid	Primary Desal Usage (lb/day):	4082.4
	Operating Factor:	0.98
	Total Sodium Hypochlorite Usage (lb/yr):	1460285
Scale Inhibitor	Primary Usage (lbs/day):	278.3
	Operating Factor:	0.98
	Total Scale Inhibitor Usage (lbs/yr):	99565
Sodium Hypochlorite	Finished Water Usage (lb/day):	371.1
	Operating Factor:	0.98
	Total Sodium Hypochlorite Usage (lb/yr):	132753

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Design Water

<i>Cartridge Filters</i>		Number of Primary Desal Cartridge Filter Elements:	552
		Replacement Events per Year:	3
		Number of Filters Replaced Per Year:	1655
<i>Membranes</i>		Primary Desal Flux Rate (gfd):	13.2
		Membrane Area per Element (ft ²):	400
		Number of Primary Desal Membrane Elements:	1681
		Replacement Events per Year:	0.2
		Number of 8-in Membrane Elements Replaced Per Year:	336
<i>Chemical Cleanings</i>			
Primary RO			
		Number of Trains to Clean Per Cleaning Event:	5.0
		Number of Cleaning Steps Per Train:	3.0
		Step 1 Solution Volume (gal):	3000
		Step 1 Cleaning Solution Strength (% by wt.):	8.0%
		Step 1 Cleaning Chemical Requirement (lbs):	2001.6
		Step 2 Solution Volume (gal):	3000
		Step 2 Cleaning Solution Strength (% by wt.):	4.0%
		Step 2 Cleaning Chemical Requirement (lbs):	1000.8
		Step 3 Solution Volume (gal):	3000
		Step 3 Cleaning Solution Strength (% by wt.):	4.0%
		Step 3 Cleaning Chemical Requirement (lbs):	1000.8
		Step 1 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	10008.0
		Step 2 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	5004.0
		Step 3 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	5004.0
		Number of Step 1 Cleaning Events Per Year:	3.0
		Number of Step 2 Cleaning Events Per Year:	3.0
		Number of Step 3 Cleaning Events Per Year:	4.0
		Step 1 Cleaning Chemical Requirement Per Year (lbs):	30024
		Step 2 Cleaning Chemical Requirement Per Year (lbs):	15012
		Step 3 Cleaning Chemical Requirement Per Year (lbs):	20016

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Design Water

<u>Maintenance Costs</u>		Miscellaneous Equipment and Building Maintenance (\$/yr):	\$150,000
		Annual Well Maintenance (\$/yr):	\$300,000
<u>Laboratory Costs</u>		Sample Analysis (\$/yr):	\$50,000
<u>Concentrate Disposal Costs</u>		Usage @ \$750/AF (\$/yr):	\$1,831,980
		Estimated Annual Concentrate Flow Measurement Station Costs (\$/yr):	\$45,000
<u>Labor Cost</u>		Number of Grade T2 Operators (No.):	3
		Annual T2 Operator Salary (\$/yr):	\$72,696
		Number of Grade T1 Operators (No.):	2
		Annual T1 Operator Salary (\$/yr):	\$59,821
		Total Raw Salary (\$/yr):	\$337,730
		Fringe Percentage (%):	40%
		Administrative Cost Percentage (%):	55%
		Total Labor Cost Per Year (\$/yr):	\$732,874
<u>O&M Cost Summary:</u>			
<u>Power</u>		Percentage Adder for Misc Power (%):	2%
		Total Power Cost (\$/yr):	\$2,418,782
<u>Chemicals</u>			
Lime			\$309,049
Sulfuric Acid			\$43,809
Scale Inhibitor			\$94,587
Sodium Hypochlorite			\$46,464
Step 1 Cleaning			\$84,668
Step 2 Cleaning			\$47,438
Step 3 Cleaning			\$40,032
<u>Membranes</u>			\$168,100
<u>Cartridge Filters</u>			\$19,865
<u>Maintenance Costs</u>			\$450,000
<u>Laboratory Costs</u>			\$50,000
<u>Concentrate Disposal Costs</u>			\$1,876,980
<u>Labor</u>			\$732,874
		Annual O&M Cost (\$/yr):	\$6,382,647
		Annual O&M Cost (\$/kgal):	\$2.005
		Annual O&M Cost (\$/AF):	\$653
<u>Amortized Capital Cost</u>		Capital Cost (\$):	\$85,137,023
		Interest (%):	3.22%
		Life Span of Investment (yrs):	30
		Amortized Capital Cost (\$/yr):	\$4,468,057
		Annual O&M Cost with Capital Recovery (\$/yr):	\$10,850,705
		Annual O&M Cost with Capital Recovery (\$/kgal):	\$3.408
		Annual O&M Cost with Capital Recovery (\$/AF):	\$1,111

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Design Water

<i>Unit Costs</i>		
	Power (\$/kWh):	\$0.125
	Lime (slaked) (\$/lb):	\$0.20
	Sulfuric Acid (\$/lb):	\$0.03
	Scale Inhibitor (\$/lb):	\$0.95
	Sodium Hypochlorite (\$/lb):	\$0.35
	Membrane Elements - 8 inch diameter(\$/element):	\$500.00
	Cartridge Filters (\$/filter):	\$12.00
	Step 1 Cleaning Chemical Cost (\$/lb):	\$2.82
	Step 2 Cleaning Chemical Cost (\$/lb):	\$3.16
	Step 3 Cleaning Chemical Cost (\$/lb):	\$2.00
	Plant Operating Factor:	0.98
<i>Well 1</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	226
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	156.3
	Power (kW):	116.6
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	1000848
<i>Well 2</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	200
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	138.4
	Power (kW):	103.2
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	885706
<i>Well 3</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	188
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	130.1
	Power (kW):	97.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	832564
<i>Well 4</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	194
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	134.2
	Power (kW):	100.1
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	859135
<i>Well 5</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	211
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	146.0
	Power (kW):	108.8
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	934420

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Design Water

<i>Well 6</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	213
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	147.3
	Power (kW):	109.9
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	943277
<i>Well 7</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	191
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	132.1
	Power (kW):	98.5
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	845849
<i>Well 8</i>	Flowrate (gpm):	1931
	Discharge Head (ft):	179
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	123.8
	Power (kW):	92.3
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	792707
<i>Well 9</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 10</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 11</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 12</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Design Water

RO Feed Pumps		
	Number of Pumps:	10.0
	Flowrate Per Pump (gpm):	1545
	Discharge Head (ft):	552
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	305.5
	Power (kW):	227.8
	Operational Factor:	0.98
	Yearly Power Usage Per Pump - Existing (kWh/yr):	1955958
	Total Yearly Power Usage (kWh/yr):	19559581
Primary RO Stage 2 Boost Pumps		
	Number of Pumps:	10.0
	Flowrate Per Pump (gpm):	655
	Discharge Head (ft):	508
	Pump Efficiency (%):	74.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	120.8
	Power (kW):	90.1
	Operational Factor:	0.98
	Yearly Power Usage Per Pump (kWh/yr):	773598
	Total Yearly Power Usage (kWh/yr):	7735982
Product Water Pumps		
	Total Number of Pumps:	4.0
	Flowrate Per Pump (gpm):	3090
	Discharge Head (ft):	123
	Pump Efficiency (%):	84.0%
	Motor Efficiency (%):	92.5%
	Power (hp):	123.5
	Power (kW):	92.1
	Operational Factor:	0.98
	Total Yearly Power Usage (kWh/yr):	3163100
Chemical Usage		
Lime	Post Treatment (lbs/day):	8639.9
	Operating Factor:	0.98
	Total Lime Usage (lbs/yr):	3090495
Sulfuric Acid	Primary Desal Usage (lb/day):	8164.9
	Operating Factor:	0.98
	Total Sodium Hypochlorite Usage (lb/yr):	2920570
Scale Inhibitor	Primary Usage (lbs/day):	556.7
	Operating Factor:	0.98
	Total Scale Inhibitor Usage (lbs/yr):	199130
Sodium Hypochlorite	Finished Water Usage (lb/day):	742.3
	Operating Factor:	0.98
	Total Sodium Hypochlorite Usage (lb/yr):	265506

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Design Water

<i>Cartridge Filters</i>		Number of Primary Desal Cartridge Filter Elements:	1104
		Replacement Events per Year:	3
		Number of Filters Replaced Per Year:	3311
<i>Membranes</i>		Primary Desal Flux Rate (gfd):	13.2
		Membrane Area per Element (ft ²):	400
		Number of Primary Desal Membrane Elements:	3362
		Replacement Events per Year:	0.2
		Number of 8-in Membrane Elements Replaced Per Year:	672
<i>Chemical Cleanings</i>			
Primary RO			
		Number of Trains to Clean Per Cleaning Event:	10.0
		Number of Cleaning Steps Per Train:	3.0
		Step 1 Solution Volume (gal):	3000
		Step 1 Cleaning Solution Strength (% by wt.):	8.0%
		Step 1 Cleaning Chemical Requirement (lbs):	2001.6
		Step 2 Solution Volume (gal):	3000
		Step 2 Cleaning Solution Strength (% by wt.):	4.0%
		Step 2 Cleaning Chemical Requirement (lbs):	1000.8
		Step 3 Solution Volume (gal):	3000
		Step 3 Cleaning Solution Strength (% by wt.):	4.0%
		Step 3 Cleaning Chemical Requirement (lbs):	1000.8
		Step 1 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	20016.0
		Step 2 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	10008.0
		Step 3 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	10008.0
		Number of Step 1 Cleaning Events Per Year:	3.0
		Number of Step 2 Cleaning Events Per Year:	3.0
		Number of Step 3 Cleaning Events Per Year:	4.0
		Step 1 Cleaning Chemical Requirement Per Year (lbs):	60048
		Step 2 Cleaning Chemical Requirement Per Year (lbs):	30024
		Step 3 Cleaning Chemical Requirement Per Year (lbs):	40032

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Design Water

<u>Maintenance Costs</u>		Miscellaneous Equipment and Building Maintenance (\$/yr):	\$150,000
		Annual Well Maintenance (\$/yr):	\$600,000
<u>Laboratory Costs</u>		Sample Analysis (\$/yr):	\$50,000
<u>Concentrate Disposal Costs</u>		Usage @ \$750/AF (\$/yr):	\$3,663,960
		Estimated Annual Concentrate Flow Measurement Station Costs (\$/yr):	\$45,000
<u>Labor Cost</u>		Number of Grade T2 Operators (No.):	3
		Annual T2 Operator Salary (\$/yr):	\$72,696
		Number of Grade T1 Operators (No.):	2
		Annual T1 Operator Salary (\$/yr):	\$59,821
		Total Raw Salary (\$/yr):	\$337,730
		Fringe Percentage (%):	40%
		Administrative Cost Percentage (%):	55%
		Total Labor Cost Per Year (\$/yr):	\$732,874
<u>O&M Cost Summary:</u>			
<u>Power</u>		Percentage Adder for Misc Power (%):	2%
		Total Power Cost (\$/yr):	\$4,788,029
<u>Chemicals</u>			
Lime			\$618,099
Sulfuric Acid			\$87,617
Scale Inhibitor			\$189,173
Sodium Hypochlorite			\$92,927
Step 1 Cleaning			\$169,335
Step 2 Cleaning			\$94,876
Step 3 Cleaning			\$80,064
<u>Membranes</u>			\$336,200
<u>Cartridge Filters</u>			\$39,730
<u>Maintenance Costs</u>			\$750,000
<u>Laboratory Costs</u>			\$50,000
<u>Concentrate Disposal Costs</u>			\$3,708,960
<u>Labor</u>			\$732,874
		Annual O&M Cost (\$/yr):	\$11,737,885
		Annual O&M Cost (\$/kgal):	\$1.844
		Annual O&M Cost (\$/AF):	\$601
<u>Amortized Capital Cost</u>		Capital Cost (\$):	\$147,965,936
		Interest (%):	3.22%
		Life Span of Investment (yrs):	30
		Amortized Capital Cost (\$/yr):	\$7,765,368
		Annual O&M Cost with Capital Recovery (\$/yr):	\$19,503,252
		Annual O&M Cost with Capital Recovery (\$/kgal):	\$3.063
		Annual O&M Cost with Capital Recovery (\$/AF):	\$998

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Worst Case Water

<i>Unit Costs</i>		
	Power (\$/kWh):	\$0.125
	Lime (slaked) (\$/lb):	\$0.20
	Sulfuric Acid (\$/lb):	\$0.03
	Scale Inhibitor (\$/lb):	\$0.95
	Sodium Hypochlorite (\$/lb):	\$0.35
	Membrane Elements - 8 inch diameter(\$/element):	\$500.00
	Cartridge Filters (\$/filter):	\$12.00
	Step 1 Cleaning Chemical Cost (\$/lb):	\$2.82
	Step 2 Cleaning Chemical Cost (\$/lb):	\$3.16
	Step 3 Cleaning Chemical Cost (\$/lb):	\$2.00
	Plant Operating Factor:	0.98
<i>Well 1</i>	Flowrate (gpm):	1717
	Discharge Head (ft):	217
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	133.4
	Power (kW):	99.5
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	854214
<i>Well 2</i>	Flowrate (gpm):	1717
	Discharge Head (ft):	196
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	120.5
	Power (kW):	89.9
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	771549
<i>Well 3</i>	Flowrate (gpm):	1717
	Discharge Head (ft):	187
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	115.0
	Power (kW):	85.7
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	736120
<i>Well 4</i>	Flowrate (gpm):	1717
	Discharge Head (ft):	179
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	110.1
	Power (kW):	82.1
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	704628
<i>Well 5</i>	Flowrate (gpm):	1717
	Discharge Head (ft):	190
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	116.8
	Power (kW):	87.1
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	747930

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Worst Case Water

<i>Well 6</i>	Flowrate (gpm):	0
	Discharge Head (ft):	140
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
<i>Well 7</i>	Yearly Power Usage (kWh/yr):	0
	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
<i>Well 8</i>	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
<i>Well 9</i>	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
<i>Well 10</i>	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
<i>Well 11</i>	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
	Flowrate (gpm):	0
	Discharge Head (ft):	250
<i>Well 12</i>	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
	Flowrate (gpm):	0

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Worst Case Water

<i>RO Feed Pumps</i>		
	Number of Pumps:	5.0
	Flowrate Per Pump (gpm):	1717
	Discharge Head (ft):	644
	Pump Efficiency (%):	80.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	371.5
	Power (kW):	277.1
	Operational Factor:	0.98
	Yearly Power Usage Per Pump - Existing (kWh/yr):	2378453
	Total Yearly Power Usage (kWh/yr):	11892266
<i>Primary RO Stage 2 Boost Pumps</i>		
	Number of Pumps:	5.0
	Flowrate Per Pump (gpm):	888
	Discharge Head (ft):	462
	Pump Efficiency (%):	74.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	148.9
	Power (kW):	111.1
	Operational Factor:	0.98
	Yearly Power Usage Per Pump (kWh/yr):	953442
	Total Yearly Power Usage (kWh/yr):	4767212
<i>Product Water Pumps</i>		
	Total Number of Pumps:	2.0
	Flowrate Per Pump (gpm):	3090
	Discharge Head (ft):	155
	Pump Efficiency (%):	82.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	156.9
	Power (kW):	117.0
	Operational Factor:	0.98
	Total Yearly Power Usage (kWh/yr):	2009041
<i>Chemical Usage</i>		
Lime	Post Treatment (lbs/day):	5418.5
	Operating Factor:	0.98
	Total Lime Usage (lbs/yr):	1938197
Sulfuric Acid	Primary Desal Usage (lb/day):	4536.0
	Operating Factor:	0.98
	Total Sodium Hypochlorite Usage (lb/yr):	1622539
Scale Inhibitor	Primary Usage (lbs/day):	536.1
	Operating Factor:	0.98
	Total Scale Inhibitor Usage (lbs/yr):	191755
Sodium Hypochlorite	Finished Water Usage (lb/day):	371.1
	Operating Factor:	0.98
	Total Sodium Hypochlorite Usage (lb/yr):	132753

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Worst Case Water

<i>Cartridge Filters</i>		Number of Primary Desal Cartridge Filter Elements:	613
		Replacement Events per Year:	3
		Number of Filters Replaced Per Year:	1839
<i>Membranes</i>		Primary Desal Flux Rate (gfd):	13.2
		Membrane Area per Element (ft ²):	400
		Number of Primary Desal Membrane Elements:	1681
		Replacement Events per Year:	0.2
		Number of 8-in Membrane Elements Replaced Per Year:	336
<i>Chemical Cleanings</i>			
Primary RO			
		Number of Trains to Clean Per Cleaning Event:	5.0
		Number of Cleaning Steps Per Train:	3.0
		Step 1 Solution Volume (gal):	3000
		Step 1 Cleaning Solution Strength (% by wt.):	8.0%
		Step 1 Cleaning Chemical Requirement (lbs):	2001.6
		Step 2 Solution Volume (gal):	3000
		Step 2 Cleaning Solution Strength (% by wt.):	4.0%
		Step 2 Cleaning Chemical Requirement (lbs):	1000.8
		Step 3 Solution Volume (gal):	3000
		Step 3 Cleaning Solution Strength (% by wt.):	4.0%
		Step 3 Cleaning Chemical Requirement (lbs):	1000.8
		Step 1 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	10008.0
		Step 2 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	5004.0
		Step 3 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	5004.0
		Number of Step 1 Cleaning Events Per Year:	3.0
		Number of Step 2 Cleaning Events Per Year:	3.0
		Number of Step 3 Cleaning Events Per Year:	4.0
		Step 1 Cleaning Chemical Requirement Per Year (lbs):	30024
		Step 2 Cleaning Chemical Requirement Per Year (lbs):	15012
		Step 3 Cleaning Chemical Requirement Per Year (lbs):	20016

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Worst Case Water

<u>Maintenance Costs</u>		Miscellaneous Equipment and Building Maintenance (\$/yr):	\$150,000
		Annual Well Maintenance (\$/yr):	\$300,000
<u>Laboratory Costs</u>		Sample Analysis (\$/yr):	\$50,000
<u>Concentrate Disposal Costs</u>		Usage @ \$750/AF (\$/yr):	\$2,849,747
		Estimated Annual Concentrate Flow Measurement Station Costs (\$/yr):	\$45,000
<u>Labor Cost</u>		Number of Grade T2 Operators (No.):	3
		Annual T2 Operator Salary (\$/yr):	\$72,696
		Number of Grade T1 Operators (No.):	2
		Annual T1 Operator Salary (\$/yr):	\$59,821
		Total Raw Salary (\$/yr):	\$337,730
		Fringe Percentage (%):	40%
		Administrative Cost Percentage (%):	55%
		Total Labor Cost Per Year (\$/yr):	\$732,874
<u>O&M Cost Summary:</u>			
<u>Power</u>		Percentage Adder for Misc Power (%):	2%
		Total Power Cost (\$/yr):	\$2,866,577
<u>Chemicals</u>			
Lime			\$387,639
Sulfuric Acid			\$48,676
Scale Inhibitor			\$182,167
Sodium Hypochlorite			\$46,464
Step 1 Cleaning			\$84,668
Step 2 Cleaning			\$47,438
Step 3 Cleaning			\$40,032
<u>Membranes</u>			\$168,100
<u>Cartridge Filters</u>			\$22,072
<u>Maintenance Costs</u>			\$450,000
<u>Laboratory Costs</u>			\$50,000
<u>Concentrate Disposal Costs</u>			\$2,894,747
<u>Labor</u>			\$732,874
		Annual O&M Cost (\$/yr):	\$8,021,454
		Annual O&M Cost (\$/kgal):	\$2.520
		Annual O&M Cost (\$/AF):	\$821
<u>Amortized Capital Cost</u>		Capital Cost (\$):	\$85,137,023
		Interest (%):	3.22%
		Life Span of Investment (yrs):	30
		Amortized Capital Cost (\$/yr):	\$4,468,057
		Annual O&M Cost with Capital Recovery (\$/yr):	\$12,489,511
		Annual O&M Cost with Capital Recovery (\$/kgal):	\$3.923
		Annual O&M Cost with Capital Recovery (\$/AF):	\$1,278

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Worst Case Water

<i>Unit Costs</i>	
	Power (\$/kWh): \$0.125
	Lime (slaked) (\$/lb): \$0.20
	Sulfuric Acid (\$/lb): \$0.03
	Scale Inhibitor (\$/lb): \$0.95
	Sodium Hypochlorite (\$/lb): \$0.35
	Membrane Elements - 8 inch diameter(\$/element): \$500.00
	Cartridge Filters (\$/filter): \$12.00
	Step 1 Cleaning Chemical Cost (\$/lb): \$2.82
	Step 2 Cleaning Chemical Cost (\$/lb): \$3.16
	Step 3 Cleaning Chemical Cost (\$/lb): \$2.00
	Plant Operating Factor: 0.98
<i>Well 1</i>	Flowrate (gpm): 1907
	Discharge Head (ft): 226
	Pump Efficiency (%): 75.0%
	Motor Efficiency (%): 94.0%
	Power (hp): 154.4
	Power (kW): 115.1
	Operational Factor: 0.98
	Yearly Power Usage (kWh/yr): 988492
<i>Well 2</i>	Flowrate (gpm): 1907
	Discharge Head (ft): 201
	Pump Efficiency (%): 75.0%
	Motor Efficiency (%): 94.0%
	Power (hp): 137.3
	Power (kW): 102.4
	Operational Factor: 0.98
	Yearly Power Usage (kWh/yr): 879145
<i>Well 3</i>	Flowrate (gpm): 1907
	Discharge Head (ft): 190
	Pump Efficiency (%): 75.0%
	Motor Efficiency (%): 94.0%
	Power (hp): 129.8
	Power (kW): 96.8
	Operational Factor: 0.98
	Yearly Power Usage (kWh/yr): 831033
<i>Well 4</i>	Flowrate (gpm): 1907
	Discharge Head (ft): 180
	Pump Efficiency (%): 75.0%
	Motor Efficiency (%): 94.0%
	Power (hp): 123.0
	Power (kW): 91.7
	Operational Factor: 0.98
	Yearly Power Usage (kWh/yr): 787294
<i>Well 5</i>	Flowrate (gpm): 1907
	Discharge Head (ft): 194
	Pump Efficiency (%): 75.0%
	Motor Efficiency (%): 94.0%
	Power (hp): 132.5
	Power (kW): 98.8
	Operational Factor: 0.98
	Yearly Power Usage (kWh/yr): 848528

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Worst Case Water

<i>Well 6</i>	Flowrate (gpm):	1907
	Discharge Head (ft):	210
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	143.5
	Power (kW):	107.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	918510
<i>Well 7</i>	Flowrate (gpm):	1907
	Discharge Head (ft):	212
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	144.8
	Power (kW):	108.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	927258
<i>Well 8</i>	Flowrate (gpm):	1907
	Discharge Head (ft):	191
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	130.5
	Power (kW):	97.3
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	835407
<i>Well 9</i>	Flowrate (gpm):	1907
	Discharge Head (ft):	179
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	122.3
	Power (kW):	91.2
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	782921
<i>Well 10</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 11</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0
<i>Well 12</i>	Flowrate (gpm):	0
	Discharge Head (ft):	250
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	0.0
	Power (kW):	0.0
	Operational Factor:	0.98
	Yearly Power Usage (kWh/yr):	0

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Worst Case Water

RO Feed Pumps		
	Number of Pumps:	10.0
	Flowrate Per Pump (gpm):	1717
	Discharge Head (ft):	552
	Pump Efficiency (%):	75.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	339.5
	Power (kW):	253.2
	Operational Factor:	0.98
	Yearly Power Usage Per Pump - Existing (kWh/yr):	2173287
	Total Yearly Power Usage (kWh/yr):	21732868
Primary RO Stage 2 Boost Pumps		
	Number of Pumps:	10.0
	Flowrate Per Pump (gpm):	655
	Discharge Head (ft):	508
	Pump Efficiency (%):	74.0%
	Motor Efficiency (%):	94.0%
	Power (hp):	120.8
	Power (kW):	90.1
	Operational Factor:	0.98
	Yearly Power Usage Per Pump (kWh/yr):	773598
	Total Yearly Power Usage (kWh/yr):	7735982
Product Water Pumps		
	Total Number of Pumps:	4.0
	Flowrate Per Pump (gpm):	3090
	Discharge Head (ft):	118
	Pump Efficiency (%):	84.0%
	Motor Efficiency (%):	92.5%
	Power (hp):	118.5
	Power (kW):	88.4
	Operational Factor:	0.98
	Total Yearly Power Usage (kWh/yr):	3034518
Chemical Usage		
Lime	Post Treatment (lbs/day):	10837.0
	Operating Factor:	0.98
	Total Lime Usage (lbs/yr):	3876393
Sulfuric Acid	Primary Desal Usage (lb/day):	9072.1
	Operating Factor:	0.98
	Total Sodium Hypochlorite Usage (lb/yr):	3245078
Scale Inhibitor	Primary Usage (lbs/day):	618.6
	Operating Factor:	0.98
	Total Scale Inhibitor Usage (lbs/yr):	221255
Sodium Hypochlorite	Finished Water Usage (lb/day):	742.3
	Operating Factor:	0.98
	Total Sodium Hypochlorite Usage (lb/yr):	265506

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Worst Case Water

<i>Cartridge Filters</i>		Number of Primary Desal Cartridge Filter Elements:	1226
		Replacement Events per Year:	3
		Number of Filters Replaced Per Year:	3679
<i>Membranes</i>		Primary Desal Flux Rate (gfd):	13.2
		Membrane Area per Element (ft ²):	400
		Number of Primary Desal Membrane Elements:	3362
		Replacement Events per Year:	0.2
		Number of 8-in Membrane Elements Replaced Per Year:	672
<i>Chemical Cleanings</i>			
Primary RO			
		Number of Trains to Clean Per Cleaning Event:	10.0
		Number of Cleaning Steps Per Train:	3.0
		Step 1 Solution Volume (gal):	3000
		Step 1 Cleaning Solution Strength (% by wt.):	8.0%
		Step 1 Cleaning Chemical Requirement (lbs):	2001.6
		Step 2 Solution Volume (gal):	3000
		Step 2 Cleaning Solution Strength (% by wt.):	4.0%
		Step 2 Cleaning Chemical Requirement (lbs):	1000.8
		Step 3 Solution Volume (gal):	3000
		Step 3 Cleaning Solution Strength (% by wt.):	4.0%
		Step 3 Cleaning Chemical Requirement (lbs):	1000.8
		Step 1 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	20016.0
		Step 2 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	10008.0
		Step 3 Cleaning Solution Usage Per Cleaning Event (lbs/cleaning):	10008.0
		Number of Step 1 Cleaning Events Per Year:	3.0
		Number of Step 2 Cleaning Events Per Year:	3.0
		Number of Step 3 Cleaning Events Per Year:	4.0
		Step 1 Cleaning Chemical Requirement Per Year (lbs):	60048
		Step 2 Cleaning Chemical Requirement Per Year (lbs):	30024
		Step 3 Cleaning Chemical Requirement Per Year (lbs):	40032

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Worst Case Water

<u>Maintenance Costs</u>		Miscellaneous Equipment and Building Maintenance (\$/yr):	\$150,000
		Annual Well Maintenance (\$/yr):	\$600,000
<u>Laboratory Costs</u>		Sample Analysis (\$/yr):	\$50,000
<u>Concentrate Disposal Costs</u>		Usage @ \$750/AF (\$/yr):	\$5,699,494
		Estimated Annual Concentrate Flow Measurement Station Costs (\$/yr):	\$45,000
<u>Labor Cost</u>		Number of Grade T2 Operators (No.):	3
		Annual T2 Operator Salary (\$/yr):	\$72,696
		Number of Grade T1 Operators (No.):	2
		Annual T1 Operator Salary (\$/yr):	\$59,821
		Total Raw Salary (\$/yr):	\$337,730
		Fringe Percentage (%):	40%
		Administrative Cost Percentage (%):	55%
		Total Labor Cost Per Year (\$/yr):	\$732,874
<u>O&M Cost Summary:</u>			
<u>Power</u>		Percentage Adder for Misc Power (%):	2%
		Total Power Cost (\$/yr):	\$5,138,500
<u>Chemicals</u>			
Lime			\$775,279
Sulfuric Acid			\$97,352
Scale Inhibitor			\$210,193
Sodium Hypochlorite			\$92,927
Step 1 Cleaning			\$169,335
Step 2 Cleaning			\$94,876
Step 3 Cleaning			\$80,064
<u>Membranes</u>			\$336,200
<u>Cartridge Filters</u>			\$44,144
<u>Maintenance Costs</u>			\$750,000
<u>Laboratory Costs</u>			\$50,000
<u>Concentrate Disposal Costs</u>			\$5,744,494
<u>Labor</u>			\$732,874
		Annual O&M Cost (\$/yr):	\$14,316,237
		Annual O&M Cost (\$/kgal):	\$2.248
		Annual O&M Cost (\$/AF):	\$733
<u>Amortized Capital Cost</u>		Capital Cost (\$):	\$147,965,936
		Interest (%):	3.22%
		Life Span of Investment (yrs):	30
		Amortized Capital Cost (\$/yr):	\$7,765,368
		Annual O&M Cost with Capital Recovery (\$/yr):	\$22,081,605
		Annual O&M Cost with Capital Recovery (\$/kgal):	\$3.468
		Annual O&M Cost with Capital Recovery (\$/AF):	\$1,130

APPENDIX E – DETAILED CAPITAL COST ESTIMATE

Carollo Engineers, Inc.

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 10,000 AFY - Worst Case Water

	Units	Unit Costs	Quantity	Cost
Drilled and Equipped Wells ¹	EA	\$2,500,000	6	\$15,000,000
North Wellfield Pipelines				
12" HDPE	LF	\$79	4550	\$359,450
20" HDPE	LF	\$136	3150	\$428,400
24" HDPE	LF	\$167	2700	\$450,900
30" HDPE	LF	\$229	1350	\$309,150
36" HDPE	LF	\$253	1400	\$354,200
South Wellfield Pipelines				
12" HDPE	LF	\$79	0	\$0
20" HDPE	LF	\$136	0	\$0
24" HDPE	LF	\$167	0	\$0
30" HDPE	LF	\$229	0	\$0
36" HDPE	LF	\$253	0	\$0
Sand Separators	EA	\$88,550	2	\$177,100
Cartridge Filters	EA	\$46,000	3	\$138,000
RO Feed Pumps	EA	\$275,000	5	\$1,375,000
RO Systems	GPD	\$0.45	8900000	\$4,005,000
RO CIP System	EA	\$155,000	1	\$155,000
RO Flush/Plant Water Pumps	EA	\$35,000	4	\$140,000
RO Flush Tank	EA	\$150,000.00	1	\$150,000
Product Water Storage Tank	gal	\$1.00	1990000	\$1,990,000
Finished Water Pumps	EA	\$175,000	3	\$525,000
Product Water Pipeline	LF	\$304	30530	\$9,281,120
Concentrate Pipeline	LF	\$106	1400	\$148,400
SMP Connection Station	EA	\$300,000	1	\$300,000
Lime Feed System	EA	\$747,500	1	\$747,500
Sodium Hypochlorite Feed System	EA	\$67,500	1	\$67,500
Scale Inhibitor Storage and Feed	EA	\$67,500	1	\$67,500
Building, Non-Process Area ²	FT ²	\$250	4048	\$1,012,000
Building, Process Area ²	FT ²	\$200	7850	\$1,570,000
Covered Chemical Storage	FT ²	\$75	2200	\$165,000
Sitework ³	%	5%		\$614,230
Electrical & I/C ⁴	%	30%		\$3,685,380
Mechanical ⁵	%	25%		\$2,384,400
Direct Cost Subtotal				\$45,600,230
Contingency	%	25%		\$11,400,058
Subtotal				\$57,000,288
Sales Tax ⁶	%	9%		\$2,565,013
Subtotal				\$59,565,300
Contractor General Conditions	%	6%		\$3,573,918
Subtotal				\$63,139,218
Contractor Overhead and Profit	%	12%		\$7,576,706
Subtotal				\$70,715,925
Escalation to Midpoint ⁷	%	2.9%		\$2,050,762
TOTAL CONSTRUCTION COSTS				\$72,766,686
Engineering and Contract Administration (20%)	%	17%		\$12,370,337
TOTAL PROJECT COST¹²				\$85,137,023

1. Based on CDA Phase III Expansion well costs

2. Includes general building HVAC and plumbing.

3. Includes demolition, excavation, paving, sidewalks, landscaping and general site improvements. Excludes pipelines and wells.

4. Electrical for desalter site facilities only and does not include backup power. Well electrical costs included in well equipment unit costs

5. Estimate for onsite piping, valves, supports, etc. HVAC and plumbing included in building per square foot cost.

6. Estimated as sales tax*(0.5*direct cost+contingency)

7. Assumes 18 month construction schedule.

Carollo Engineers, Inc.

Project: South Oxnard Plain Feasibility Study
 Client: UWCD
 Option: 20,000 AFY - Worst Case Water

	Units	Unit Costs	Quantity	Cost
Drilled and Equipped Wells ¹	EA	\$2,500,000	12	\$30,000,000
North Wellfield Pipelines				
12" HDPE	LF	\$79	4550	\$359,450
20" HDPE	LF	\$136	3150	\$428,400
24" HDPE	LF	\$167	2700	\$450,900
30" HDPE	LF	\$229	1350	\$309,150
36" HDPE	LF	\$253	1400	\$354,200
South Wellfield Pipelines				
12" HDPE	LF	\$79	3075	\$242,925
20" HDPE	LF	\$136	1600	\$217,600
24" HDPE	LF	\$167	3100	\$517,700
30" HDPE	LF	\$229	0	\$0
36" HDPE	LF	\$253	3950	\$999,350
Sand Separators	EA	\$88,550	4	\$354,200
Cartridge Filters	EA	\$46,000	6	\$276,000
RO Feed Pumps	EA	\$275,000	10	\$2,750,000
RO Systems	GPD	\$0.45	17800000	\$8,010,000
RO CIP System	EA	\$155,000	1	\$155,000
RO Flush/Plant Water Pumps	EA	\$35,000	4	\$140,000
RO Flush Tank	EA	\$150,000.00	1	\$150,000
Product Water Storage Tank	gal	\$1.00	4010000	\$4,010,000
Finished Water Pumps	EA	\$175,000	5	\$875,000
Product Water Pipeline	LF	\$425	30530	\$12,975,250
Concentrate Pipeline	LF	\$136	1400	\$190,400
SMP Connection Station	EA	\$300,000	1	\$300,000
Lime Feed System	EA	\$747,500	1	\$747,500
Sodium Hypochlorite Feed System	EA	\$67,500	1	\$67,500
Scale Inhibitor Storage and Feed	EA	\$67,500	1	\$67,500
Building, Non-Process Area ²	FT ²	\$250	4048	\$1,012,000
Building, Process Area ²	FT ²	\$200	15700	\$3,140,000
Covered Chemical Storage	FT ²	\$75	2200	\$165,000
Sitework ³	%	5%		\$1,095,985
Electrical & I/C ⁴	%	30%		\$6,575,910
Mechanical ⁵	%	25%		\$4,400,675
Direct Cost Subtotal				\$81,337,595
Contingency	%	25%		\$20,334,399
Subtotal				\$101,671,994
Sales Tax ⁶	%	9%		\$4,575,240
Subtotal				\$106,247,233
Contractor General Conditions	%	6%		\$6,374,834
Subtotal				\$112,622,067
Contractor Overhead and Profit	%	12%		\$13,514,648
Subtotal				\$126,136,716
Escalation to Midpoint ⁷	%	2.9%		\$3,657,965
TOTAL CONSTRUCTION COSTS				\$129,794,680
Engineering and Contract Administration (20%)	%	14%		\$18,171,255
TOTAL PROJECT COST¹²				\$147,965,936

1. Based on CDA Phase III Expansion well costs

2. Includes general building HVAC and plumbing.

3. Includes demolition, excavation, paving, sidewalks, landscaping and general site improvements. Excludes pipelines and wells.

4. Electrical for desalter site facilities only and does not include backup power. Well electrical costs included in well equipment unit costs

5. Estimate for onsite piping, valves, supports, etc. HVAC and plumbing included in building per square foot cost.

6. Estimated as sales tax*(0.5*direct cost+contingency)

7. Assumes 18 month construction schedule.